



# City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

APR 9 1992

March 24, 1992

Paul C. Roybal  
Holmes & Narver, Inc.  
6501 Americas Parkway, NE  
Albuquerque, New Mexico 87110

RE: DRAINAGE PLAN FOR THE FOURTH STREET FUELING FACILITY  
(J-14/D98) & 4309.90 ENGINEER'S STAMP DATED MARCH 6, 1992

Dear Mr. Roybal:

Based on the information provided on your submittal of March 9, 1992, the following concerns must be addressed prior to final approval.

- ✓ 1. Bench Marks - location, description and elevation
  - a. Albuquerque Control Survey Vertical Datum used. - "Z-H14"
  - b. Temporary bench mark on site permanently marked. R.R. SPIKE in P.P.
- ✓ 2. Site Description
  - ✓ a. Vicinity map, please include the zone atlas map index number. H14 ; J14
  - ⓑ Legal description or current plat. - "see Attached"
3. Flow volumes and rates - calculations showing on-site undeveloped and developed flow volumes and rates. Use attached emergency rule criteria for your calculations. - *Shown on Plan*
4. Are there any off-site flows entering from the surrounding properties? *No*
- Ⓢ New or proposed elevations must be determined and not estimated.  
*"As per telephone conversation"*

PUBLIC WORKS DEPARTMENT

Paul C. Roybal  
March 23, 1992  
Page 2

6. Please include the as-built information on the existing catch basin and the invert at the outlet of the sidewalk culvert. *Not Available As per telephone conversation.*
7. Engineer's Certification per the DPM Engineer's Certification Checklist will be required prior to Certificate of Occupancy release.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

*Bernie J. Montoya*  
Bernie J. Montoya, C.E.  
Engineering Assistant

BJM/bsj  
(WP+3259)