



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

June 26, 1992

Kim R. Kemper
Kemper-Vaughan
3700 Coors Road, NW
Albuquerque, New Mexico

RE: DRAINAGE PLAN FOR AN ADDITION TO KASDORF MANUFACTURING, PHASE I
(J-14/D99) ENGINEER'S STAMP DATED JUNE 8, 1992

Dear Mr. Kemper:

Based on the information provided on your submittal of June 8, 1992, the above referenced plan is approved for Building Permit.

Please be advised that when Phase II submittal is submitted for review, all the developed runoff must be routed to First Street, NW. Catch basin within the parking lot with a tie to the existing inlet on First Street will be appropriate.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya, C.E.
Engineering Assistant

xc: Cecil Kasdorf
Joe Slagle
Alan Martinez

BJM/bjf
(WP+3439)

PUBLIC WORKS DEPARTMENT