

Date: 6/8/01

ATTN: Loren Meinz
COA Hydrology

PROJECT: Bernalillo County Metropolitan Court Parking Structure

PROJECT NO: **20018**

We Transmit the Following:

Copies	Date	Description
1	6/7/01	Revised SO19 Sheet


If enclosures are not as noted, please inform us immediately.

Remarks:

Loren,

Here is the revised grading sheet showing the 6" water block at the property line as discussed. We have managed to make the site still drain without the addition of a storm drain inlet and connection to the line. There is a swale at the west side of the structure that drains into a new SW culvert. Also, the roof drainage pattern is shown.

If you should have any additional questions, or if I may be of further assistance, do not hesitate to call.



By: Nicole M. Losack, EI

cc: file, gjackson

BPLW

Architects & Engineers, Inc.

6200 Uptown Blvd. NE
Suite 220
Albuquerque, New Mexico 87110
(505)881-2759 FAX (505)881-1230

49 West First Street
Suite 100
Mesa, Arizona 85201
(602)827-2759
FAX (602)827-0386

☐ Acknowledge receipt of enclosures.
☐ Return enclosures to us.
☐ Via facsimile
fax number:
Original will be mailed:
☐ Yes ☐ No