

CITY OF ALBUQUERQUE
PUBLIC WORKS DEPARTMENT
UTILITY DEVELOPMENT DIVISION/HYDROLOGY SECTION

PRE-DESIGN CONFERENCE

DRAINAGE FILE/ZONE ATLAS PAGE NO.: J-142 DATE: 2-8-94
EPC NO.: _____ DRB NO.: _____ ZONE: SD-2
SUBJECT: Law Office Addition
STREET ADDRESS: 708 Marquette NW (7th & Marquette, SW)
LEGAL DESCRIPTION: Lot 4 & 5 N portion 6-11 Perfecto Arroyo
B/K I

APPROVAL REQUESTED: _____ PRELIMINARY PLAT _____ FINAL PLAT
_____ SITE DEVELOPMENT PLAN ☒ BUILDING PERMIT
_____ GRADING/PAVING PERMIT _____ OTHER _____

	WHO	REPRESENTING
ATTENDANCE:	<u>Raymond Hensley, P.E.</u>	<u>CAME</u>
	<u>John Duhigg</u>	<u>Duhigg, Cronin & Sperry (OWNER)</u>
	<u>John Curtin</u>	<u>C.O.A./PWU/Hyd</u>

FINDINGS:

Panel 28 shows site in Zone B.
Project is an infill site. Discharge
is limited to existing rate. All
discharge to the street must be
thru a driveway or a sidewalk
culvert (which would require an S.O.A).
Check off-site flows. Survey
must be mean sea level.

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: <u>[Signature]</u>	SIGNED: <u>[Signature]</u>
TITLE: <u>CE/Hydrology</u>	TITLE: <u>Engineer</u>
DATE: <u>2-8-94</u>	DATE: <u>2/7/94</u>

NOTE PLEASE PROVIDE A COPY OF THIS PRE-DESIGN FORM WITH THE DRAINAGE SUBMITTAL.