



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

February 2, 1996

Tom Blaine, PE
Leedshill-Herkenhoff, Inc
500 Copper Ave. NW
Albuquerque, NM 87103

**RE: LA AMISTAD SENIOR HOUSING (J14-D113) GRADING PLAN FOR
GRADING PERMIT APPROVAL. ENGINEER'S STAMP DATED 1-12-96.**


Dear Mr. Blaine:

Based on the information provided on your January 26, 1996 submittal, the above referenced project is approved for Grading Permit.

I am assuming that an existing finish floor elevation will be used as a temporary bench mark and that all finish floor elevations shown are correct. An Engineer's Certification will be required. You will have to show that the project ties into a City of Albuquerque permanent bench mark prior to final acceptance.

If I can be of further assistance, please feel free to contact me at 768-3622.

Sincerely,



Lisa Ann Manwill
Engineering Assoc./Hyd.

c: Andrew Garcia
File