

Public Works Department

March 5, 1997

Martin J. Chávez, Mayor

Robert E. Gurulé, Director

Celia Tomlinson, P.E.
RHOMBUS P.A., Inc.
2620 San Mateo NE
Suite B
Albuquerque, NM 87110

**RE: TAPIA LAW OFFICE (J14-D117). GRADING AND DRAINAGE PLAN
SUBMITTAL FOR PRELIMINARY PLAT, FINAL PLAT, AND PRELIMINARY
PLAT APPROVALS. ENGINEER'S STAMP DATED FEBRUARY 25, 1997.**


Dear Ms Tomlinson:

Based on the information provided on your February 26, 1997
submittal, City Hydrology has the following comment:

1. Simply stating that you will pond in the landscaped areas
is too vague. Show pond elevations and exact locations.

If I can be of further assistance, please feel free to contact me at
924-3984.

Sincerely,



Lisa Ann Manwill, P.E.
Engineering Assoc./Hyd.

c: Andrew Garcia
File

Good for You, Albuquerque!

