



BRASHER & LORENZ, INC.
CONSULTING ENGINEERS

2201 San Pedro NE Bldg 1 Suite 220 • Albuquerque, NM 87110 • Phone (505) 888-6088 • Fax (505) 888-6188 • www.brasherlorenz.com

July 5, 2001

John Murray, PE
Public Works Department/Hydrology
City of Albuquerque
600 Second Street NW
Albuquerque, NM 87103

SUBJECT: GRADING & DRAINAGE PLAN FOR BAGLEY STUDIO
J-14/D140


Dear John:

Submitted herewith are 2 copies of the revised Grading and Drainage Plan for the subject project. The Plan has been revised to eliminate the French drain concept and instead recommends an area drain that connects to the public 18-inch storm drain in First Street. I've discussed this with Loren Miens, and he feels it can be permitted through the SO#19 process.

Thank you for your attention on this matter. If you have any questions, please call.

Sincerely,

BRASHER & LORENZ, INC.


Dennis A. Lorenz, PE
Principal

/dl/01516
encl

