


CITY OF ALBUQUERQUE



November 2, 2004

Scott McGee, P.E.
Isaacson & Arfman, P.A.
128 Monroe St. NE
Albuquerque, NM 87108

**Re: Urology Network of New Mexico, 610 Broadway Blvd NE, Grading and
Drainage Plan**
Engineer's Stamp dated 9-17-04 (J14-D148)

Dear Mr. McGee,

Based upon the information provided in your submittal received 9-17-04, the
above referenced plan cannot be approved for Building Permit until the following
comments are addressed:

P.O. Box 1293

Albuquerque

1. Ponding / Water Harvesting is not allowed within the City Right of Way.
2. Please include a copy of the drainage calculations.
3. Where is the proposed storm drain detail referred to in note 17?

If you have any questions, you can contact me at 924-3986.

New Mexico 87103

www.cabq.gov

Sincerely,

Bradley L. Bingham, PE
Principal Engineer, Planning Dept.
Development and Building Services

C: File

5 wtr. meters
abandon
& cap to
main line
middle of
block