

CITY OF ALBUQUERQUE



October 6, 2014

Gilbert Aldez, P.E.
Applied Engineering & Surveying Inc.
1605 Blair Drive NE
Albuquerque, NM 87122

**RE: Cuatro Development
Erosion and Sediment Control (ESC) Plan (J14E173)
Engineers Stamp Dates 9-17-14**

Dear Mr. Aldez:

Based upon the information provided in your submittal received 9-17-2014, the above referenced ESC plan is acceptable for Building Permit based on the following comment:

PO Box 1293 _ Include NPDES Posting Board. Posting Board should be visible from Public Street.

Albuquerque Please attach a copy of the plans to the construction sets prior to sign-off by Hydrology. This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge for disturbing one acre or more and a Topsoil Disturbance Permit for disturbing $\frac{3}{4}$ of an acre or more.

New Mexico 87103

If you have any questions, you can contact me at 924-3999.

www.cabq.gov

Sincerely,

Shahab Biazar, P.E.
Acting City Engineer, Planning Dept.
Development Review Services

C: e-mail