Cherne, Curtis

From: Cherne, Curtis

Sent: Friday, April 10, 2015 8:10 AM

To: 'Kevin Cobos'

Subject: RE: SWPPP at Greater Albuquerque housing on 4th street

Kevin,

Thank you for your prompt response. I have to go to a conference Tuesday through Friday about noon.

If Monday is OK, I would prefer to do it Monday. Say 10:30 AM?

- OK
- 2. Cold mix would be good. Thanks.
- 3. I could have sworn a posting board was required per the CGP. I quickly read through it yesterday and could not find anything. My apologies.

Have a good weekend.

Curtis

From: Kevin Cobos [mailto:kcobos@Tofelconstruction.com]

Sent: Thursday, April 09, 2015 3:19 PM

To: Cherne, Curtis **Cc:** George Schlegel

Subject: RE: SWPPP at Greater Albuquerque housing on 4th street

Curtis, I am currently working on the items listed below, Just let me know when you would like to meet on site and I will make myself available.

- 1.silt fence will be repaired
- 2. due to over excavation my entrance had to go in this place for safety concerns. I actually have cold patch for the ramp if this is an issue I will fix immediately.
- 3. the sign, is there a specific SWPP sign that needs to be hung? Or the fugitive dust sign only?

From: Cherne, Curtis [mailto:CCherne@cabq.gov]

Sent: Thursday, April 9, 2015 10:22 AM

To: Kevin Cobos

Subject: SWPPP at Greater Albuquerque housing on 4th street

Kevin,

Good morning.

MY name is Curtis Cherne. I am the SWPPP compliance engineer for the Planning Department in Albuquerque.

I stopped by your site on 4th street today.

Overall the site looked pretty good with the following exceptions:

- 1. 25 feet of silt fence needs repair on Summer Ave.
- 2. The construction entrance was moved away from the curb cut, so dirt is being used as a ramp.
- 3. I couldn't find the required posting board per the Construction General Permit.

I visited the job trailer and hung out for a little while.

I would like to schedule a meeting next week to go through your SWPPP and see that the above exceptions have been remedied.

Curtis Cherne, P.E. Stormwater Quality Engineer 505-924-3420

Spam
Not spam
Forget previous vote