

OPTION 20 – SWMM MODEL OUTPUT

Option Description

This option was not modeled using SWMM; however, approximate calculations were carried out based on the attached discussion.

All proposed system curves and calculations that were approximated are attached.

Appendix Volume 1.2 Option 20 Facility X14

**SIMPLE COMPUTATION OF THE REQUIRED
FORCE MAIN DIAMETER FOR****OPTION 20 - FACILITY X14****Location –**

From Broadway Pump Station follow the same alignment as the existing 54-inch force main to Mountain, then west on Mountain towards the Rio Grande – see Figure attached for the alignment

Purpose –

The purpose of Option 20 Facility X14, was to determine if an alternate route for the Broadway Pump Station force main would provide an increase pipe capacity and assist in the achieving the existing pump station capacity of 130 cfs, or the proposed capacity of 150 cfs if it is rebuilt. The concept was derived assuming that pumping downhill with an outfall to the Rio Grande may be more efficient than pumping uphill to the North Diversion Channel. Option 20 was not modeled in SWMM. The additional purpose of this Option is to determine the cost differences of this option as compared to the other pump station force main improvement options.

Facility X14 –

Pump capacity at Broadway Pump Station at 130 or 150 cfs with a new pump station. This would also require an additional new 54-in. force main to the Rio Grande beginning at Mountain and continuing west. See Figure attached for the possible alignment.

Broadway Lift Station Options

The Broadway Storm Water Lift Station No. 31 currently discharges to the North Diversion Channel (about 1.3 miles along Broadway Boulevard and Mountain Road). The current pumping capacity is 127 CFS (*Molzen Corbin and Associates, Broadway Pump Station DAR, July 2008*). The maximum static head at the pumps is about 177 feet (based on as-builts of the station, and contours at the Channel inlet). The existing discharge pipe is a 54-inch diameter concrete cylinder pipe. The report recommended that when the pumps are replaced (due to age and maintenance issues), they should be up-sized to pump this maximum capacity of the discharge pipe (increase of 23 CFS would provide 150 cfs capacity).

The city requested that Smith Engineering Company (SEC) perform a simple computation to examine an alternative to pump replacement, that could increase the capacity of the station.

Appendix Volume 1.2 Option 20 Facility X14


This alternative was to discharge (downstream) to the Rio Grande. This would decrease the static head, and therefore increase the capacity. In order to examine the pumping capacity of the existing pumps with a different discharge scenario, a manufactures pump curve is necessary. However, no pump curves are available and therefore, SEC “assumed” a pump curve based on the know information including the existing system curve (Appendix A, EXIST 54” line) and a known operating point (see point 1 illustrated in the chart in attached). SEC proposed one possible route from the pump station to the Rio Grande (see Figure attached for alignment).

The route would be from the station west on Mountain Road, to 12th Street, to Fruit Street, to Central, to Laguna to the Rio Grande (about 2.7 miles). The discharge from the existing pumps through this proposed pipeline depends upon the pipe diameter of the force main. Essentially, as the pipe diameter increases, the discharge increases.

The Chart attached illustrates the system curves for proposed pipe sizes varying from 42-inch to 60-inch diameter. Only a 48-inch diameter or larger pipe would result in an increased capacity of the existing pumps (>127 CFS). A 48-inch diameter pipe would result in an increase of 15 CFS (142 CFS total); a 60-inch discharge pipe would result in an increased capacity of 29 CFS (156 CFS total).

CONCLUSION –

A 54-inch discharge pipe would allow a capacity of 150 cfs and that would match the proposed pump station capacity if the station is rebuilt per the DAR report described previously.




 NOT TO SCALE

MID-VALLEY DRAINAGE MANAGEMENT PLAN

FOR THE CITY OF ALBUQUERQUE &
 ALBUQUERQUE METROPOLITAN ARROYO
 FLOOD CONTROL AUTHORITY

October - 2011

SEC PROJECT NO. 110112

POSSIBLE NEW FORCEMAIN ALIGNMENTS

FIGURE 6-2


Mid-Valley DMP

Smith Engineering Company

Approximate Calculations for Proposed Broadway Pump Station Curves prepared by Smith Engineering Company

System Curves									
System Curve Data									
	Existing System	Proposed System		Proposed System		Proposed System		Proposed System	
Total Pipe Length (ft)	6884	14500		14500		14500		14500	
Minor Loss Equivalent Length (ft)	698.4	1450		1450		1450		1450	
Total Equivalent Length (ft)	7582.4	15950		15950		15950		15950	
Pipe Diameter (in)	54	42		48		54		60	
Min H ₂ O C	130	120	DIP	120	DIP	120	DIP	120	DIP
High Upstream WSE (ft)	4953	4953	Top of the wet well	4953	Top of the wet well	4953	Top of the wet well	4953	Top of the wet well
Low Upstream WSE (ft)	4936	4936	Bottom of the wet well - 3'	4936	Bottom of the wet well - 3'	4936	Bottom of the wet well - 3'	4936	Bottom of the wet well - 3'
High Downstream WSE (ft)	51-3	4950	Rio Grande	4950	Rio Grande	4950	Rio Grande	4950	Rio Grande
Maximum Static Lift (ft)	177	14		14		14		14	
	EXIST 54"	NEW 42"		NEW 48"		NEW 54"		NEW 60"	
	EXISTING MAX/ WW LO (C=120)	PROPOSED MAX/ WW LO (C=120)		PROPOSED MAX/ WW LO (C=120)		PROPOSED MAX/ WW LO (C=120)		PROPOSED MAX/ WW LO (C=120)	
CFS	GPM	TDH	Vel FPS	TDH	Vel FPS	TDH	Vel FPS	TDH	Vel FPS
0	0	177	0.0	14	0.0	14	0.0	14	0.0
11	5000	177	0.7	16	0.7	16	0.7	16	0.7
22	10000	178	1.4	22	1.4	22	1.4	22	1.4
33	15000	179	2.1	30	2.1	30	2.1	30	2.1
45	20000	181	2.7	38	2.7	38	2.7	38	2.7
56	25000	183	3.4	46	3.4	46	3.4	46	3.4
72	32331	187	4.4	61	4.4	61	4.4	61	4.4
76	35000	188	4.8	62	4.8	62	4.8	62	4.8
96	44006	194	6.0	78	6.0	78	6.0	78	6.0
100	45000	195	6.2	79	6.2	79	6.2	79	6.2
111	50000	196	6.9	84	6.9	84	6.9	84	6.9
127	56998	204	7.8	105	7.8	105	7.8	105	7.8
134	60000	207	8.2	114	8.2	114	8.2	114	8.2
145	65000	212	8.9	124	8.9	124	8.9	124	8.9
162	72745	220	10.0	142	10.0	142	10.0	142	10.0
167	75000	222	10.3	146	10.3	146	10.3	146	10.3
178	80000	228	11.0	160	11.0	160	11.0	160	11.0
189	85000	234	11.7	174	11.7	174	11.7	174	11.7
201	90000	241	12.4	188	12.4	188	12.4	188	12.4
212	95000	247	13.1	202	13.1	202	13.1	202	13.1
223	100000	254	13.7	216	13.7	216	13.7	216	13.7
234	105000	262	14.4	230	14.4	230	14.4	230	14.4
245	110000	269	15.1	244	15.1	244	15.1	244	15.1

Approximate Broadway Pump Station System Curves Prepared By Smith Engineering Company



-----Original Message-----

From: Pat Conley, PE [<mailto:patc@smithengineering.pro>]

Sent: Thursday, July 28, 2011 2:21 PM

To: 'Curtin, John P.'; 'Pat Stovall'

Cc: 'Rebecca Fink'; 'Penttila, Roland V.'; 'Eisenberg, Jame J.'; 'Bingham, Brad'

Subject: RE: Pat Stovall - FW: New Broadway force main

John,

As I recall, the discussion during our meeting was that we would look at this to see if it was even feasible before we send in a proposal to increase the contract price. If the head losses are the same either way, it would not make sense to spend any more time or money to investigate this if the pumps were not going to be upsized (which is what we understand).

The scope of this work will fit into our overall schedule and that is what we intended to do after we got past the deadlines to which Pat S. is referring. I don't believe that either Pat S. or myself understood this to be a future improvements option that needed immediate attention and I don't remember it being addressed in this manner. We are still going to proceed with our brief analysis to look at the feasibility of this.

Please call me to discuss.

Thanks

-----Original Message-----

From: Curtin, John P. [<mailto:JCurtin@cabq.gov>]

Sent: Thursday, July 28, 2011 10:54 AM

To: Pat Stovall

Cc: Rebecca Fink; Pat Conley; Penttila, Roland V.; Eisenberg, Jame J.

Subject: RE: Pat Stovall - FW: New Broadway force main

8/9/2011

Too bad! We have still decided to go with brand x.

John P. Curtin, P.E. Senior Engineer

Storm Drainage Design Section, Engineering Division

Department of Municipal Development, City of Albuquerque

Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Pat Stovall [<mailto:pats@smithengineering.pro>]

Sent: Thursday, July 28, 2011 10:50 AM

To: Curtin, John P.

Cc: Rebecca Fink; Pat Conley

Subject: RE: Pat Stovall - FW: New Broadway force main

Hi John

Just got your email below,

Sorry we were not more responsive to your emails

We have all been very overwhelmed with deadlines

That are now past.

Pat

-----Original Message-----

From: Curtin, John P. [<mailto:JCurtin@cabq.gov>]

Sent: Thursday, July 28, 2011 10:39 AM

To: Pat Stovall; Pat Conley, PE

Cc: Rebecca Fink; Penttila, Roland V.; Eisenberg, Jame J.

Subject: RE: Pat Stovall - FW: New Broadway force main

8/9/2011

Since we have not received a proposal from you, we rescinding the request and talking to brand x.

Thank You, John P. Curtin, P.E. Senior Engineer
Storm Drainage Design Section, Engineering Division
Department of Municipal Development, City of Albuquerque
Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Rebecca Fink [<mailto:rebeccaf@smithengineering.pro>]

Sent: Tuesday, July 26, 2011 8:26 AM

To: Curtin, John P.

Cc: 'Pat Stovall'

Subject: RE: Pat Stovall - FW: New Broadway force main

John,

Can you get me copy of the existing pump curves (or a manufacturer and model

number), so I can quickly determine if increased capacity of the existing

pumps is possible?

Thanks,

Becky

-----Original Message-----

From: Pat Stovall [<mailto:pats@smithengineering.pro>]

Sent: Thursday, July 21, 2011 12:50 PM

To: Rebecca Fink

Subject: Pat Stovall - FW: New Broadway force main

-----Original Message-----

From: Curtin, John P. [mailto:]

Sent: Thursday, July 21, 2011 11:28 AM

To: Pat Conley; Pat Stovall

Cc: Penttila, Roland V.; Brad Bingham PE

Subject: RE: New Broadway force main

P & P,

Please bring Becky into this discussion. My impression from our conversation was that pumps designed for low head & high flow were rare (or at least the selection was limited and I assumed that translated into expensive). Instead of guessing I would like to hear from an expert.

Thank You, John P. Curtin, P.E. Senior Engineer

Storm Drainage Design Section, Engineering Division

Department of Municipal Development, City of Albuquerque

Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Penttila, Roland V.

Sent: Thursday, July 21, 2011 10:58 AM

To: Curtin, John P.; 'Pat Conley'; 'Pat Stovall'

Cc: 'Brad Bingham PE'

8/9/2011

Subject: RE: New Broadway force main

I'm assuming (that may be bad) that the costs for new pumps at the station are going to be almost the same for high head, low flow or high flow, low head. So, what I'm most interested in is the additional cost of a new force main to the river abandoning the current one to the NDC.
forwarded by:

Roland Penttila, P.E.

Manager, Storm Drainage Design Section

Engineering Division; City of Albuquerque

768-2778

-----Original Message-----

From: Curtin, John P.

Sent: Wednesday, July 20, 2011 2:50 PM

To: 'Pat Conley'; 'Pat Stovall'

Cc: Penttila, Roland V.; Brad Bingham PE

Subject: RE: New Broadway force main

P&P,

I talked to Becky and she said that this is not a simple matter of head, but a combination of head & flow. To pump to the Rio, it would be a case of low head & high flow, which is not the standard application (It would require a different pump than it would take to go to the NDC).
Roland/Brad,

I believe that Jerry requires a cost analysis of a pump station & force main that would meet the following criteria:

8/9/2011

Q=250 cfs

13,000 lf of 36" Force Main

Is this what you want SEC to give us a proposal for?

Thank You, John P. Curtin, P.E. Senior Engineer

Storm Drainage Design Section, Engineering Division

Department of Municipal Development, City of Albuquerque

Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Curtin, John P.

Sent: Wednesday, July 20, 2011 12:29 PM

To: Penttila, Roland V.

Cc: Pat Conley

Subject: RE: New Broadway force main

Smith is preparing a quick and dirty evaluation of the head required to push the water to the NDC vs to the River. If additional work is required, then they will submit a proposal for an additional service.

Thank You, John P. Curtin, P.E. Senior Engineer

Storm Drainage Design Section, Engineering Division

Department of Municipal Development, City of Albuquerque

Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Penttila, Roland V.

8/9/2011

Sent: Wednesday, July 20, 2011 12:21 PM

To: Curtin, John P.

Subject: New Broadway force main

Has Smith told you when they may provide us with a quote for the additional engineering?

Message from Roland's iPhone4

Pat Stovall

From: Curtin, John P. [JCurtin@cabq.gov]
To: Wednesday, July 27, 2011 9:35 AM
Cc: Rebecca Fink; Penttila, Roland V.; Brad Bingham PE
Subject: Pat Stovall; Pat Conley, PE
RE: Pat Stovall - FW: New Broadway force main

As a point of reference, I believe that Pump station #47, at Rio Grande & Montano, is the closest to the alternate force main that we are considering for Broadway. Based on the 1986 Wilson Report for #47, four 11,220 gpm pumps push 95 cfs thru 2,750 lf of 48" diameter force main at 7.56 fps. If we assume that 8 fps is a reasonable velocity:

Q36" FM = 8 fps * 7.07 sf = 56.5 cfs

Q54" FM = 8 fps * 15.9 sf = 127 cfs

Q72" FM = 8 fps * 28.3 sf = 226 cfs

I realize that this is simplistic, but I believe that it indicates that a 36" force main is unrealistic.

Thank You, John P. Curtin, P.E. Senior Engineer Storm Drainage Design Section, Engineering Division Department of Municipal Development, City of Albuquerque
Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Curtin, John P.
To: Tuesday, July 26, 2011 2:36 PM
Cc: 'Rebecca Fink'
Subject: 'Pat Stovall'; 'Pat Conley, PE'; Penttila, Roland V.; 'Brad Bingham PE'
Subject: RE: Pat Stovall - FW: New Broadway force main

Becky,

Additional Service #3 will be a cost benefit study of a Force Main to the River. It will be constrained by the Pump Station Layout in the Molzen-Corbin Report. Basically the City wants to know how many cfs we can pump to the River and how much it will cost for the Force Main and any modification required for the Pumps. Give me a call and I will try to answer any questions that you have.

Thank You, John P. Curtin, P.E. Senior Engineer Storm Drainage Design Section, Engineering Division Department of Municipal Development, City of Albuquerque
Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Rebecca Fink [mailto:rebeccaf@smithengineering.pro]
Sent: Tuesday, July 26, 2011 8:26 AM
To: Curtin, John P.
Cc: 'Pat Stovall'
Subject: RE: Pat Stovall - FW: New Broadway force main

John,

Can you get me copy of the existing pump curves (or a manufacturer and model number), so I can quickly determine if increased capacity of the existing pumps is possible?

Thanks,
Becky

-----Original Message-----

From: Pat Stovall [mailto:pats@smithengineering.pro]
Sent: Thursday, July 21, 2011 12:50 PM
To: Rebecca Fink
Subject: Pat Stovall - FW: New Broadway force main

-----Original Message-----

From: Curtin, John P. [mailto:]
Sent: Thursday, July 21, 2011 11:28 AM
To: Pat Conley; Pat Stovall
Cc: Penttila, Roland V.; Brad Bingham PE
Subject: RE: New Broadway force main

P & P,

Please bring Becky into this discussion. My impression from our conversation was that pumps designed for low head & high flow were rare (or at least the selection was limited and I assumed that translated into expensive). Instead of guessing I would like to hear from an expert.

Thank You, John P. Curtin, P.E. Senior Engineer
Storm Drainage Design Section, Engineering Division
Department of Municipal Development, City of Albuquerque
Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Penttila, Roland V.
Sent: Thursday, July 21, 2011 10:58 AM
To: Curtin, John P.; 'Pat Conley'; 'Pat Stovall'
Cc: 'Brad Bingham PE'
Subject: RE: New Broadway force main

I am assuming (that may be bad) that the costs for new pumps at the station are going to be almost the same for high head, low flow or high flow, low head. So, what I'm most interested in is the additional cost of a new force main to the river abandoning the current one to the NDC.

forwarded by:

Roland Penttila, P.E.
Manager, Storm Drainage Design Section
Engineering Division; City of Albuquerque
768-2778

-----Original Message-----

From: Curtin, John P.
Sent: Wednesday, July 20, 2011 2:50 PM
To: 'Pat Conley'; 'Pat Stovall'
Cc: Penttila, Roland V.; Brad Bingham PE
Subject: RE: New Broadway force main

P&P,

I talked to Becky and she said that this is not a simple matter of head, but a combination of head & flow. To pump to the Rio, it would be a case of low head & high flow, which is not the standard application (It would require a different pump than it would take to go to the NDC).

Roland/Brad,

I believe that Jerry requires a cost analysis of a pump station & force main that would meet the following criteria:

Q=250 cfs

13,000 lf of 36" Force Main

Is this what you want SEC to give us a proposal for?

Thank You, John P. Curtin, P.E. Senior Engineer
Storm Drainage Design Section, Engineering Division
Department of Municipal Development, City of Albuquerque
Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Curtin, John P.

Sent: Wednesday, July 20, 2011 12:29 PM

To: Penttala, Roland V.

Cc: Pat Conley

Subject: RE: New Broadway force main

Smith is preparing a quick and dirty evaluation of the head required to push the water to the NDC vs to the River. If additional work is required, then they will submit a proposal for an additional service.

Thank You, John P. Curtin, P.E. Senior Engineer
Storm Drainage Design Section, Engineering Division
Department of Municipal Development, City of Albuquerque
Tel: 768-2727 FAX: 768-2765

-----Original Message-----

From: Penttala, Roland V.

Sent: Wednesday, July 20, 2011 12:21 PM

To: Curtin, John P.

Subject: New Broadway force main

Has Smith told you when they may provide us with a quote for the additional engineering?

Message from Roland's iPhone4



PROJECT _____ SHEET NO. _____ OF _____
SUBJECT _____ PROJECT NO. _____
BY _____ DATE ____/____/____ CHECKED BY _____ DATE ____/____/____

Pipe Type: CONCRETE CYLINDER PIPE
 $\phi = 54"$

Distance = 1.3 mi. = 6864 A

Project # _____

BG AS #2

ELEV 4978' - Google Earth



size 54"
length 6864
type REP

Length = 6864 A
= 1.3 mi

ELEV 5144' - Google Earth
Discharge Point @
N. Div. Channel.