

CITY OF ALBUQUERQUE



July 18, 2012

Levi Valdez, P.E.
George Rodriguez Development & Consulting
12800 San Juan NE
Albuquerque, NM 87123

Re: Duplex Addition, 5401 Marble NE
Request for Permanent C.O. – Not Accepted
Engineer's Stamp dated: 12-04-12, (J18/D042)
Certification dated: 07-16-13

Dear Mr. Rodriguez,

Based upon the information provided in the Certification received 07-17-13, the above referenced Certification is unacceptable for release of a Permanent Certificate of Occupancy by Hydrology.

PO Box 1293


1. The swale is not in place behind the Duplex.
2. The retention ponds were not complete.

Albuquerque

If you have any questions, you can contact me at 924-3695 or Rudy Rael at 924-3977.

Sincerely,

New Mexico 87103


Shahab Biazar, P.E.
Senior Engineer—Hydrology, Planning Dept.
Development and Building Services

www.cabq.gov

RR/SB
C: File