

CITY OF ALBUQUERQUE



June 29, 2012

Fred C. Arfman, P.E.
Isaacson & Arfman, P.A.
128 Monroe St NE
Albuquerque, NM 87108

**Re: GARCIA VOLKSWAGEN
Grading and Drainage Plan
Engineer's Stamp Date 6/26/2012 (J19/D003)**

Dear Mr. Arfman,

Based upon the information provided in your submittal received 6/27/2012, the grading and Drainage Plan is approved for Building Permit.

PO Box 1293

Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology. Prior to Certificate of Occupancy release, Engineer Certification per the DPM checklist will be required.

Albuquerque


Albuquerque's MS4 Permit became effective March 1st, 2012. Grading and Drainage Plans and Drainage Reports will have to comply with the requirements of the new permit (<http://www.cabq.gov/planning/landcoord/Hydrology.html>).

NM 87103

If you have any questions, you can contact me at 924-3695.

www.cabq.gov

Sincerely,


Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: e-mail

DRAINAGE AND TRANSPORTATION INFORMATION SHEET
(Rev. 12/05)

PROJECT TITLE: Garcia Volkswagon - Building Addition ZONE MAP/DRG.FILE# J-19 / D003
DRB#: _____ EPC#: _____ WORK ORDER#: _____

LEGAL DESCRIPTION: Lot 17A1, Block 23, East End Addition, Albuquerque, NM
CITY ADDRESS: 8201 Lomas Blvd. NE

ENGINEERING FIRM: ISAACSON AND ARFMAN CONTACT: Fred Arfman
ADDRESS: 128 MONROE N.E. PHONE: 268-8828
CITY, STATE: ALBUQUERQUE, NM ZIP CODE: 87108

OWNER: _____ CONTACT: _____
ADDRESS: _____ PHONE: _____
CITY, STATE: _____ ZIP CODE: _____

ARCHITECT: Van H. Gilbert Architects CONTACT: Michael Borowski, AIA
ADDRESS: 2428 Baylor Dr. SE PHONE: 247-9955
CITY, STATE: Albuquerque, NM ZIP CODE: 87106

SURVEYOR: _____ CONTACT: _____
ADDRESS: _____ PHONE: _____
CITY, STATE: _____ ZIP CODE: _____

CONTRACTOR: _____ CONTACT: _____
ADDRESS: _____ PHONE: _____
CITY, STATE: _____ ZIP CODE: _____

TYPE OF SUBMITTAL:

- ☐ DRAINAGE REPORT
☐ DRAINAGE PLAN 1st SUBMITTAL
☒ DRAINAGE PLAN RESUBMITTAL
☐ CONCEPTUAL G & D PLAN
☒ GRADING PLAN
☐ EROSION CONTROL PLAN
☐ ENGINEER'S CERT (HYDROLOGY)
☐ CLOMR/LOMR
☐ TRAFFIC CIRCULATION LAYOUT
☐ ENGINEER/ARCHITECT CERT (TCL)
☐ ENGINEER/ARCHITECT CERT (DRB S.P.)
☐ ENGINEER/ARCHITECT CERT (AA)
☐ OTHER (SPECIFY) _____

CHECK TYPE OF APPROVAL SOUGHT:

- ☐ SIA/FINANCIAL GUARANTEE RELEASE
☐ PRELIMINARY PLAT APPROVAL
☐ S. DEV. PLAN FOR SUB'D APPROVAL
☐ S. DEV. FOR BLDG. PERMIT APPROVAL
☐ SECTOR PLAN APPROVAL
☐ FINAL PLAT APPROVAL
☐ FOUNDATION PERMIT APPROVAL
☒ BUILDING PERMIT APPROVAL
☐ CERTIFICATE OF OCCUPANCY (PERM)
☐ CERTIFICATE OF OCCUPANCY (TEMP)
☐ GRADING PERMIT APPROVAL
☐ PAVING PERMIT APPROVAL
☐ WORK ORDER APPROVAL
☐ OTHER (SPECIFY) _____

WAS A PRE-DESIGN CONFERENCE ATTENDED:

- ☐ YES
☐ NO
☐ COPY PROVIDED

DEC 27
JUN 27 2012

SUBMITTED BY: Fred Arfman DATE: June 26, 2012
Isaacson & Arfman, P.A.

Requests for approvals of Site Development Plans and/or Subdivision Plats shall be accompanied by a drainage submittal. The particular nature, location and scope to the proposed development define the degree of drainage detail. One or more of the following levels of submittal may be required based on the following:

1. **Conceptual Grading and Drainage Plan:** Required for approval of Site Development Plans greater than five (5) acres and Sector Plans.
2. **Drainage Plans:** Required for building permits, grading permits, paving permits and site plans less than five (5) acres.
3. **Drainage Report:** Required for subdivision containing more than ten (10) lots or constituting five (5) acres or more.