

CITY OF ALBUQUERQUE



May 8, 2012

Scott A. Eddings, P.E.
Huitt-Zollars
6501 Americas Parkway NE
Albuquerque, NM 87110

**Re: BJ Restaurant- Winrock Mall, Conceptual Grading and Drainage Plan
Engineer's Stamp Date 4-13-12 (J19-D058A)**

Dear Mr. Eddings,

Based upon the information provided in your submittal received with a DRB packet, the above referenced plan is approved for Site Plan for Building Permit action by the DRB.

Hydrology provides the comment concerning the portion of the narrative that states "overflows shall by-pass the inlet and flow around the building in an earthen swale..." will be revised with the Building Permit submittal since an earthen swale is not shown on the plan.

PO Box 1293

If you have any questions, you can contact me at 924-3986.

Albuquerque

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Planning Dept.
Development and Building Services

NM 87103

www.cabq.gov

C: e-mail