



# City of Albuquerque Stormwater Construction Site Inspection Report

General Information					
ESC File No.	J20E028	Project Name:	NuVue		
NPDES Id. No.	NMR10069N & NMR10069Z	Location:	1171 Jaffa Rd. NE		
4/14/2025	Owner -		Contractor		
Operator	4740 Dillon Drive, LLC		Harrison Construction LLC		
Contact name & title	Malik Hasan		Patrick Audenis		
e-mail	<a href="mailto:accounts@nuvuepharma.com">accounts@nuvuepharma.com</a>		<a href="mailto:harrisonbuildinginc@hotmail.com">harrisonbuildinginc@hotmail.com</a>		
Contact Phone #	919-619-2443		949-278-1727		
COA Inspector	James Hughes		Start/End Time:	12pm	
Construction Phase:	footer excavation				
Type of Inspection:	<input type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Past Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input checked="" type="checkbox"/> Follow Up
Weather at time of inspection?	clear		Temperature:	~ 60	
Estimated date of last storm 0.25" or greater	11/7/2024				
Item Number	Deficiency/ Corrective Action				
1	Posting - The permit coverage posting sign was missing in violation of CGP Part 1.5. Required mitigation: You must post a sign or other public notice of your permit coverage at a safe, publicly available location in close proximity to the construction site per CGP Part 1.5. The notice must be located so it is visible from the public road that is nearest to the active part of the construction site, and it must use a font large enough to be readily viewed from a public right-of-way.				
2	BMPs - The silt fence has not been maintained and has collapsed in violation of CGP Part 2.1.4. Required mitigation: Ensure all stormwater controls are maintained and remain in effective operating condition during permit coverage and are protected from activities that would reduce their effectiveness per CGP Part 2.1.4.				
3					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	ok	Latest report Date:	3/29/2025	
Notes:					
The replacement SWPPP was in a bucket east of the entrance, was inspected on 4/4/25, and only had two self-inspection reports. The SWPPP certifications weren't signed, and the delegation of authority to Paul Julian was missing.					

City of Albuquerque Stormwater Inspector Signature and date: 7/24/2025  
Contact information: Doug Hughes (505) 924-3420  
[jhughes@cabq.gov](mailto:jhughes@cabq.gov)

Chancellor English