

# CITY OF ALBUQUERQUE



January 23, 2018

John Nourzad P.E.  
GreenbergFarrow  
1430 W. Peachtree St NW  
Atlanta, Ga 30309

**Re: Murphy Express -1358 Wyoming Blvd NE  
Erosion Sediment Control Plan  
Engineer's Stamp Date 11-15-17 (J20E037)**

Dear Mr. Nourzad,

Based upon the information provided in your submittal received 1-9-18, the above referenced plan is approved to be included in the SWPPP and to apply for an Erosion and Sediment Control Permit for Grading and Building Permit with the following condition:

1. Remove the silt fence dike on pavement (SDP) BMP shown in the gutter pan and replace with silt fence/filter sock/sediment BMP at the boundary between disturbed and undisturbed, most likely inside the sidewalk.

PO Box 1293

Include a copy of the approved plan in the Building Permit set.

Albuquerque

If you have any questions, you can contact me at 924-3420.

NM 87103

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

www.cabq.gov

C: email