

CITY OF ALBUQUERQUE

Hydrology Section Planning Department
Brennon Williams, Director



Timothy M. Keller, Mayor

February 6, 2020

Mister Car Wash - David Hail – dhail@mistercarwash.com

Site: Mister Carwash at 98th St/Volcano Rd. – K08E004

Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control

Dear Mr. Hail

The following violations were observed at today's inspection.

1. Construction started without properly posting the NPDES Permit
2. The Construction Entrance was missing
3. The Silt fence was not properly installed.

The following photos were taken during the inspection today.



PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov



Required Mitigation:

1. Post NPDES Permit on perimeter of site.
2. Install BMPs per the approved ESC Plan.

If the violations are not mitigated within 7 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you have any questions, you can contact me at 924-3420 or jhughes@cabq.gov

Sincerely,

James D. Hughes, P.E.

Principal Engineer, Hydrology/Stormwater Quality
Planning Dept.