



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	K09E002	Project Name:	9101 Central Ave NW		
NPDES Id. No.	NMIR1006B5	Location:	9101 Central Ave NW		
9/18/2025	Owner	Contractor			
Operator	Cosme Jaquez	Cosme Jaquez			
Contact name & title	Cosme Jaquez	Cosme Jaquez			
e-mail	<a href="mailto:jaquez.aylin14@gmail.com">jaquez.aylin14@gmail.com</a>	<a href="mailto:jaquez.aylin14@gmail.com">jaquez.aylin14@gmail.com</a>			
Contact Phone #	505-250-7216	505-250-7216			
COA Inspector	Chancellor English	Start/End Time:	11am		
Construction Phase:	verticals				
Type of Inspection:	Regular	Storm Event	Post Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	Clear		Temperature: ~	80	
Estimated date of last storm 0.25" or greater			9/14/2025		
Item Number	Deficiency/ Corrective Action				
1	SWPPP - Your inspection reports were not available on-site for the inspection in violation of CGP Part 4.7.3. Required mitigation: You must keep a copy of all inspection reports at the site or at an easily accessible location so that they can be made immediately available at the time of an on-site inspection per CGP Part 4.7.3.				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	No	Latest report Date:	N/A	

Notes:	
The superintendent has the SWPPP in his truck.	

City of Albuquerque Stormwater Inspector Signature and date: 9/19/2025  
Contact information: Chancellor English (505) 924-3325  
[english@cabq.gov](mailto:english@cabq.gov)

*Chancellor English*