

CITY OF ALBUQUERQUE



May 1, 2013

Ronald R. Bohannon, P.E.
Tierra West, LLC.
5571 Midway Park Pl NE
Albuquerque, NM 87109

**Re: West Ridge MH Park
Grading and Drainage Plan
Engineer's Stamp date 04-15-2013 (K-09/D006)**

Dear Mr. Bohannon,

Based upon the information provided in your submittal received 04-22-13, the above referenced plan can not be approved for Grading Permit until the following comments are addressed.

- An emergency overflow needs to be added.
- Label existing contours.

If you have any questions, you can contact me at 924-3695 or Rudy Rael at 924-3977.

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

RR/SB
C: Email