

CITY OF ALBUQUERQUE



June 30, 2014

Ronald Ray Bohannon, P.E.
Tierra West, LLC
5571 Midway Park Place NE
Albuquerque, New Mexico 87109

RE: FedEx® Ground Facilities - Daytona Road NW
Town of Atrisco Grant, Unit 5, Portion of Tract 12, Tract 13 & Tract 14A
Erosion Sediment Control (ESC) Plan
Engineer's Stamp Date 5/19/2014 (K09-E026A)

Dear Mr. Bohannon,

Based upon your submittal received 5-20-14, the above referenced Erosion Sediment Control (ESC) plan is acceptable for Building Permit and Work Order based on the following conditions:

- 1) Inlet protection in Los Volcanos Road should be used only during the construction of the storm drain pipes within the right-of-way.
- 2) Please make sure that the proposed inlet protection in Los Volcanos Road will not cause flooding downstream of the project during monsoon.

PO Box 1293

Albuquerque

New Mexico 87103

This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge for disturbing one acre or more and a Topsoil Disturbance Permit for disturbing ¾ of an acre or more.

If you have any questions, you can contact me at 924-3999.

www.cabq.gov

Sincerely,

Shahab Biazar, P.E.
Acting City Engineer, Planning Dept.
Development Review Services

C: e-mail