

SOLID WASTE KEYED NOTES

- REFUSE/SOLID WASTE

GENERAL NOTES

- TREES SHALL NOT OVERHANG THE ROADWAY WHERE TRASH BINS ARE LOCATED.
- SOLID WASTE WILL BE PROVIDED ACCESS THROUGH VEHICLE GATES VIA GATE CODE AND/OR ACCESS KEY, AS APPLICABLE.
- THERE SHALL BE NO UTILITIES THAT CONFLICT WITH THE ABILITY FOR SOLID WASTE TO PICKUP THE TRASH BINS.
- SLOPES OF CONCRETE FOR TRASH ENCLOSURES WILL MEET THE REQUIREMENTS OF THE COA SOLID WASTE DEPARTMENT.
- ANY DUMPSTER THAT CONTAINS PROCESSED FOOD WILL HAVE A SANITARY SEWER DRAIN AND OUTFALL.
- ALL ROADS WHICH A SOLID WASTE VEHICLE WILL BE DRIVING ON WILL BE DESIGNED FOR EMERGENCY VEHICLES.
- CONCRETE PADS WILL BE USED FOR ALL TRASH DUMPSTER LOCATIONS. THE CONCRETE PADS WILL MEET THE MINIMUM REQUIREMENTS FOR COA SOLID WASTE.

**Bohannon
Huston**
www.bhinc.com
800.877.5332

Consultants

Copyright Notice
This drawing was prepared for use on a specific site contemporaneously with its issue date and it is not suitable for use on a different project site or at a later time. Use of this drawing for reference or example on another project requires the services of properly licensed architects and engineers. Reproduction of this drawing for reuse on another project is not authorized and may be contrary to the law.

Revisions

NO.	DATE	DESCRIPTION


PROJECT CHASE



PROJECT CHASE
90TH ST NW & LOS VOLCANES RD NW
ALBUQUERQUE, NM 87121

Project Manager:
JSP
Checked By:
BFJR
Document date:
10/07/24
Project No.
XXXXXXX
Professional Seal

Sheet Title
SOLID WASTE OVERALL
Sheet No.
SW-00

SHEET SW-01





Approved for access by the Solid Waste Department.
 All containers must be made accessible for pick up
 between the hours of 5AM and 8PM.
 Reviewer: *Adrian Marez*
 Date: 1-29-25

SOLID WASTE KEYED NOTES

- REFUSE/SOLID WASTE
- GENERAL NOTES**
- TREES SHALL NOT OVERHANG THE ROADWAY WHERE TRASH BINS ARE LOCATED.
 - SOLID WASTE WILL BE PROVIDED ACCESS THROUGH VEHICLE GATES VIA GATE CODE AND/OR ACCESS KEY, AS APPLICABLE.
 - THERE SHALL BE NO UTILITIES THAT CONFLICT WITH THE ABILITY FOR SOLID WASTE TO PICKUP THE TRASH BINS.
 - SLOPES OF CONCRETE FOR TRASH ENCLOSURES WILL MEET THE REQUIREMENTS OF THE COA SOLID WASTE DEPARTMENT.
 - ANY DUMPSTER THAT CONTAINS PROCESSED FOOD WILL HAVE A SANITARY SEWER DRAIN AND OUTFALL.
 - ALL ROADS WHICH A SOLID WASTE VEHICLE WILL BE DRIVING ON WILL BE DESIGNED FOR EMERGENCY VEHICLES.
 - CONCRETE PADS WILL BE USED FOR ALL TRASH DUMPSTER LOCATIONS. THE CONCRETE PADS WILL MEET THE MINIMUM REQUIREMENTS FOR COA SOLID WASTE.

**Bohannon
Huston**
 www.bhinc.com
 800.877.5332

Consultants

Copyright Notice
 This drawing was prepared for use on a specific site contemporaneously with its issue date and it is not suitable for use on a different project site or at a later time. Use of this drawing for reference or example on another project requires the services of properly licensed architects and engineers. Reproduction of this drawing for use on another project is not authorized and may be contrary to the law.

Revisions

NO.	DATE	DESCRIPTION


PROJECT CHASE

PROJECT CHASE
 90TH ST NW & LOS VOLCANES RD NW
 ALBUQUERQUE, NM 87121

LEGEND

- PROPERTY LINE
- ON-SITE WASTE COLLECTION TRUCK CIRCULATION
- FIRE ACCESS
- DUMPSTER
- ASPHALT PAVEMENT
- CONCRETE PAVEMENT
- GRAVEL PAVEMENT

Project Manager:
 JSP
 Checked By:
 BFIJR
 Document date:
 10/07/24
 Project No.
 XXXXXXXX
 Professional Seal



Sheet Title
SOLID WASTE - DETAIL
 Sheet No.
SW-01

9/6/2024 1:45:13 PM

W:\25-10-2025-1171\m_Plot.dwg: JPC250713
 C:\Users\jpc250713\AppData\Local\Temp\AutoCAD_2025\20250115_SW01.dwg