



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	Westpoint 40		
Location:	98th Street & Bluewater		
Site Contact Name & Agency	Brian Patterson - Titan bpatterson@titandevlopment.com	ESC File No.	K09E041
		NPDES Id. No.	Oper: NMR1002M/ Ownr: LEW
Inspection Date:	06/08/20	Start/End Time:	0740/0820hrs
CoA Stormwater Inspector:	Timothy E. Sims		
Construction Phase:	roadway construction		
Type of Inspection:	<input type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25" <input checked="" type="checkbox"/> 311/Complaint <input checked="" type="checkbox"/> Follow Up

Weather at time of inspection?	Clear	Temperature: ~	69*
Estimated date of last storm 0.25" or greater	6/1/2020		

Item Number	Deficiency/ Corrective Action		
1	Please provide latest SWPPP self-inspection report for this site. SWPPP self-inspection reports will be required for this site until final stabilization is achieved.		
2	Maveriks' site requires NPDES posting or stabilization.		
3	Silt fence requires maintenance. It appears wind damaged. Please mitigate.		
4	Waste not in acceptable container, please mitigate.		
5	A rain event occurred on 06/01/2020. Pease provide report.		
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports	requested	Latest report Date: 3/13/2020

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
 Contact information: Timothy E. Sims - (505) 803-6155
tsims@cabq.gov 06/08/20