

## City of Albuquerque Stormwater Construction Site Inspection Report

General Information							
ESC File No. K09E		041 Project Name:			Westpoint 40		
NPDES Id. No. NMR10		002M Location:		98th Street and Bluewater			
4/2	6/2021	Owner		•	Contractor		
Operator		Titan Development					
Contact name & title		Brian Patterson					
e-mail		bpatterson@Titan-Development.com					
Contact Ph	one #						
COA Inspector		Thomas Evans			Start/End Time: 1:35 PM/1:50 PM		
	tion Phase:				stabilization	<u> </u>	
Type of Ir	spection:	Regular	Storm Event	Past Storm I	Event >0.25"	311/Complaint	Follow Up
Weath	er at time of i	nspection? clear			Temperature: ~ 74		
						2/22/2021	
Item Number	Deficiency/ Corrective Action						
1	No posting of permit						
2	Repair/replace silt fence.						
3	Maintain temporary stabilization controls						
4	Install BMP's around Maverik site						
5	Stabilization on right of ways						
6	Remove and dispose of domestic waste						
2.1	Discharge off site?	(Y/N)	no				
4	Salf Inchact	ion Reports		Latest rev	oort Date:		
4	Jeli ilispect	ion Reports	Nequesteu	Latestie	Joil Date.		
Notes: Silt fence along Bluewater road looks great.							
<u> </u>							

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Thomas Evans (505-803-6215)

tevans@cabq.gov

Thomas Evans

04/27/2021