CITY OF ALBUQUERQUE

Planning Department Alan Varela, Director



March 21, 2023

Shawn Biazar SBS Construction and Engineering, LLC 7632 William Moyers Ave. NE Albuquerque, NM 87114

Re: L & C Transport Office and Shop/ Building A & B 112 94TH St. NW 30-Day Temporary Certificate of Occupancy Transportation Development Final Inspection Engineer's Stamp dated 08-03-21 (K09-D043) Certification dated 02-27-23

Dear Mrs. Biazar,

Based upon the information provided in your submittal received 03-01-22, Transportation Development has no objection to a <u>30-day Temporary Certificate of Occupancy</u> based. This letter serves as a "green tag" from Transportation Development for a <u>30-day Temporary Certificate of Occupancy</u> to be issued by the Building and Safety Division.

PO Box 1293

Prior to the issuance of a permanent Certificate of Occupancy, the following items must be addressed:

Albuquerque

Due to the closed gate, I couldn't measure the parking spaces.

NM 87103

• Please provide Motorcycle parking space. 1. Motorcycle parking spaces shall be designated by its own conspicuously posted upright sign, either free-standing or wall mounted per the zoning code. 2. The pavement marking "MC" should be shown in the opposite direction for motorcycles entering the parking space.


www.cabq.gov

- The ADA access aisles shall have the words "NO PARKING" in capital letters, each of which shall be at least one foot high and at least two inches wide, placed at the rear of the parking space so as to be close to where an adjacent vehicle's rear tire would be placed. (66-1-4.1. B NMSA 1978)
- Per approved site plan key note 03200.46: provide 6' wide ADA pathway from the public sidewalk to the building entrance.
- Driveway access off 94th must be built per approved plan.
- Please note that this CO just for Building A & B. Please request a separate CO for The Future Caretaker Residence (1,200 SF building).

Once these corrections are complete, email pictures to malnajjra@cabq.gov for release of Final CO

CITY OF ALBUQUERQUE

Planning Department Alan Varela, Director



If you have any questions, please contact me at (505) 924-3 Sincerely,

Marwa Al-najjar

Marwa Al-najjar Associate Engineer, Planning Dept. Development Review Services

ma via: email C: CO Clerk, File

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov



City of Albuquerque

Planning Department

Development & Building Services Division

DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 6/2018)

Project Title: L&C Transport Office and Shop	Building Permit #:	Hydrology File #: K09D043	
DRB#:	_ EPC#:	Work Order#:	
Legal Description: Lot 22-A, Block 8, Origina	l Townsite of Westland		
City Address:112 94TH STREET, NW			
Applicant: SBS CONSTRUCTION AND ENG	INEEING, LLC	Contact: SHAWN BIAZAR	
Address: 7632 William Moyers Avenue, NE, ALE	SUQUERQUE, NM 87114		
Phone#: (505) 804-5013	Fax#: (505) 897-4996	E-mail: AECLLC@AOL.COM	
Other Contact:		Contact:	
Address:			
Phone#:	_ Fax#:	E-mail:	
TYPE OF DEVELOPMENT: PLAT	(# of lots) RESIDENCE _	DRB SITE X ADMIN SITE	
IS THIS A RESUBMITTAL? Yes	XNo		
DEPARTMENT X TRANSPORTATION	HYDROLOGY/DRAINAC	GE	
Check all that Apply:		TYPE OF APPROVAL/ACCEPTANCE SOUGHT: BUILDING PERMIT APPROVAL	
TYPE OF SUBMITTAL: X ENGINEER/ARCHITECT CERTIFICATION	X CERTIFICA	ATE OF OCCUPANCY	
PAD CERTIFICATION			
CONCEPTUAL G & D PLAN		ARY PLAT APPROVAL	
GRADING PLAN		FOR SUB'D APPROVAL	
DRAINAGE REPORT		FOR BLDG. PERMIT APPROVAL	
DRAINAGE MASTER PLAN	FINAL PLA	AT APPROVAL	
FLOODPLAIN DEVELOPMENT PERMIT A	APPLIC		
ELEVATION CERTIFICATE	SIA/ RELEA	ASE OF FINANCIAL GUARANTEE	
CLOMR/LOMR		ION PERMIT APPROVAL	
TRAFFIC CIRCULATION LAYOUT (TCL)	· ——	PERMIT APPROVAL	
TRAFFIC IMPACT STUDY (TIS)			
STREET LIGHT LAYOUT	<u> </u>	ERMIT APPROVAL	
OTHER (SPECIFY)		PAD CERTIFICATION	
PRE-DESIGN MEETING?		DER APPROVAL	
	CLOMR/LC	AIN DEVELOPMENT PERMIT	
		PECIFY)	
DATE SUBMITTED: 2-28-2023	By: SHAWN BIAZAR		
COA STAFF:	ELECTRONIC SUBMITTAL RECEIVED:		

FEE PAID:_____

SBS CONSTRUCTION AND ENGINEERING, LLC

FEBRUARY 27, 2023

TRAFFIC ENGINEERING, PLANNING DEPT. DEVELOPMENT AND BUILDING PERMIT 600 2nd STREET, SW ALBUQUERQUE, NM 87102

RE: LOT 22-A, BLOCK 8, ORIGINAL TOWNSITE OF WESTLAND, 112 94TH STREET, NW., FINAL CERTIFICATE OF OCCUPANCY, DRB # 1011638 AMENDED DRB PROJ.# PR-2021-0055410, FILE # SI-2021-00615.

I, REZA AFAGHPOUR, NMPE OF THE SBS CONSTRUCTION AND ENGINEERING, LLC, HEREBY CERTIFY THAT THIS PROJECT IS IN SUBSTANTIAL COMPLIANCE WITH AND IN ACCORDANCE WITH THE DESIGN INTENT OF THE APPROVED AMENDED SITE PLAN FOR BUILDING PERMIT DATED 08-31-2021, DRB PROJ.# PR-2021-0055410, FILE # SI-2021-00615.

I CERTIFY THAT I HAVE PERSONALLY VISITED THE PROJECT SITE ON FEBRUARY 17TH, 2023 AND HAVE DETERMINED BY VISUAL INSPECTION THAT THE DATA PROVIDED IS REPRESENTATIVE OF ACTUAL SITE CONDITIONS AND IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF. THIS CERTIFICATION IS SUBMITTED IN SUPPORT OF A REQUEST FOR CERTIFICATE OF OCCUPANCY.

THE RECORD INFORMATION PRESENTED HEREON IS NOT NECESSARILY COMPLETE AND INTENDED ONLY TO VERIFY SUBSTANTIAL COMPLIANCE OF THE TRAFFIC ASPECTS OF THIS PROJECT. THOSE RELYING ON THE RECORD DOCUMENT ARE ADVISED TO OBTAIN INDEPENDENT VERIFICATION OF ITS ACCURACY BEFORE USING IT FOR ANY OTHER PURPOSE.

REZA AFAGHPOUR, PE

2/27/2023

DATE

ADMINISTRATIVE AMENDMENT

FILE #: SI-2021-00615 PROJECT #:	PR-2021-005410
Installation of an additional driveway along Volcano Road N	W;
Installation of a 6' tall wrought iron fence along east and sou	uth sides of property;
Illustrated detail/siting of shade structure near shop building	J.
Digitally signed by James M. Aranda DN: cn=James M. Aranda, o=City of Albuquerque, ou=Planning Department, email=jmaranda@cabq.gov, c=US Date: 2021.08.03 16:28:29 -06'00'	8/3/2021
APPROVED BY	DATE

MINOR AMENDMENT TO SITE DEVELOPMENT PLAN APPROVED PRIOR TO EFFECTIVE DATE OF IDO

<u>DESCRIPTION:</u>
THIS MINOR AMENDMENT IS FOR THE CONSTRUCTION OF AN ADDITIONAL DRIVEWAY ENTRANCE INTO THE PROPERTY, RELOCATION OF THE PEDESTRIAN GATE AND SIDEWALK INTO THE PROPERTY, AND MINOR CHANGES TO THE LANDSCAPING TO ACCOMMODATE THE

DRB PROJECT NO. 1011638

ZONING:
AT TURN IN OF DRB APPLICATION SUBMITTAL: SU-2 / IP CURRENT IDO ZONING: NR-BP THERE IS NO MASTER DEVELOPMENT PLAN ON FILE.

LOT 22-A, BLOCK NO. 8, ORIGINAL TOWNSITE OF WESTLAND, BEING A REPLAT OF LOT 22. BLOCK 8, WITHIN TOWN OF ATRISCO GRANT, BERNALILLO COUNTY.

THE USE OF THE NEW BUILDINGS SHALL REMAIN THE SAME AS PROPOSED IN THE ORIGINAL DRB APPLICATION:

BUILDING 'A' OFFICE BUILDING: 2,160 SF PORTAL / COVERED PATIO: 1.032 SF CARPORT: 805 SF **BUILDING 'B'** 4,000 SF SHOP: SHADE STRUCTURE: 3,200 SF **FUTURE CARETAKER RESIDENCE:** 1,200 SF 25' X 48' =

SPECIFIC NOTES FOR THIS MINOR AMENDMENT:

- 1. AN ADDITIONAL DRIVEWAY / CURB CUT WILL BE INSTALLED ON VOLCANO RD. NW. AN AUTOMATIC SLIDING GATE SHALL BE INSTALLED AT THAT ENTRANCE. THE ENTRANCE GATE ON 94TH ST. WILL BE A MANUAL SWING DOUBLE GATE.
- 2. PEDESTRIAN ACCESS AND GATE WILL BE FROM VOLCANO RD. NW. 3. ALL FENCING ALONG VOLCANO AND 94TH ST. WILL BE WROUGHT IRON.
- MASONRY WALLS WILL BE INSTALLED ON EACH SIDE OF THE VEHICLE GATES. 4. FOUR INTERIOR PARKING SPACES WILL BE LOCATED NORTH OF THE HANDICAP
- 5. THE SHADE STRUCTURE IS A SEPARATE STRUCTURE FROM THE SHOP BUILDING PER THE APPROVED BUILDING PERMIT SET


Site Plan 1" = 20'-0"

INDEX OF DRAWINGS: SITE DEVELOPMENT PLAN APPROVAL AS-100.1 SITE PLAN A-202.1 SITE DETAILS / SIGNAGE C-100.1 GRADING AND DRAINAGE PLAN A-200.1 BUILDING ELEVATIONS - SHOP / SHADE STRUCTURE L-100.1 LANDSCAPING PLAN LEGEND: **ABCWUA** R.O.W. LANDSCAPE: 8" THICK AGGREGATE BASE COURSE (ABC)COMPACTED

DATE TRAFFIC ENGINEERING, TRANSPORTATION DIVISION DATE GRAVEL. 3" THICK, OVER GEOTEXTILE FILTER TO 95% MIN. OVER FABRIC/ WEED BARRIER, 1/2" MAXIMUM SIZE EXISTING GRADE COMPACTED TO 95% MIN. PARKS AND RECREATION DEPARTMENT DATE ASPHALT PAVING CONSTRUCTED AS PART OF CONCRETE SIDEWALK / DRIVE / SLAB PREVIOUS CITY WORK ORDER DATE CITY ENGINEERING / HYDROLOGY NEW 6' HIGH WROUGHT IRON GATE PAINTED BLACK DATE CODE ENFORCEMENT PARKING DATA: DATE ENVIRONMENTAL HEALTH DEPARTMENT (CONDITIONAL) **PARKING REQUIREMENT**

SOLID WASTE MANAGEMENT

DRB CHAIRPERSON, PLANNING DEPARTMENT



VICINITY MAP / ZONE ATLAS PAGE K-09-Z

DATE

DATE

PARKING PROVIDED:

REQUIRED

REQUIRED

13 SPACES PROVIDED (INCLUDES 1 VAN ACCESSIBLE HC SPACE)


TOTAL NUMBER OF PARKING SPACES REQUIRED = 13

OFFICE PARKING:
 1 SPACE PER 200 OCCUPANTS: 2160 SF / 200 = 10.8, THEREFORE 11 SPACES

• 1 SPACE PER 2000 OCCUPANTS: 4000 SF / 2000 = 2, THEREFORE 2 SPACES

 1 MOTORCYCLE SPACE PROVIDED BICYCLE RACK FOR 2 BICYCLES PROVIDED

(NO BUS REDUCTION INCLUDED)



GENERAL NOTES:

- ALL SIDEWALKS, RAMPS, CURB CUTS, CURB AND GUTTER SHALL BE CONSTRUCTED PER CITY OF ALBUQUERQUE STANDARD DRAWINGS:
 - SIDEWALK (2430) RAMPS (2440)
 - CURB CUTS (2426)
 - CURB AND GUTTER (2415)
- SEE GEOTECHNICAL ENGINEERING REPORT DATED JUNE 12, 2018 PREPARED BY TERRACON. TERRACON PROJECT NO. 66185086.

KEYED NOTES:

01100.01 PROPERTY LINE.


01100.02 HATCHED AREA INDICATES 11' MINI CLEAR SIGHT TRIANGLE.

01100.06 VAN ACCESSIBLE HC PARKING. 1% MIN., 2% MAX SLOPE.

01100.07 INTERSECTION CLEAR SIGHT DISTANCE PER CITY OF ALBUQUERQUE TRAFFIC CODE, SECTION 8-2-2-15.

01100.08 EXISTING STOP SIGN. RELOCATE. 02200.07 REMOVE EXISTING CHAIN LINK FENCE.

- 4" THICK 4,000 PSI AIR-ENTRAINED CONCRETE SIDEWALK OVER GRADE COMPACTED TO 95%. REINFORCE WITH 6X6-W2.1 X W2.1WWF, FLAT SHEETS ONLY. SLOPE AWAY FROM BUILDING AT 1/8" PER FOOT MINIMUM. LIGHT BROOM FINISH.
- NEW CONCRETE SIDEWALK PER CITY OF ALBUQUERQUE STANDARD SPECIFICATIONS. REFER TO CITY STANDARD DETAIL DWG. 2430.
- THIS WORK TO BE CONTRACTED UNDER A SEPARATE CONTRACT PER COA WORK ORDER.
- 4" THICK 3000 PSI AIR-ENTRAINED CONCRETE SIDEWALK OVER GRADE COMPACTED TO 95%. REINFORCE WITH 6X6-10X10 WWM, FLAT SHEETS ONLY. SLOPE IN DIRECTION OF TRAVEL SHALL NOT EXCEED 1:20 AND CROSS SLOPE SHALL NOT EXCEED 1:48.
- CONCRETE CURB AND CURB RAMP PER COA STANDARD SPECIFICATIONS. REFER TO CITY STANDARD DETAIL DWG 2426. THIS WORK TO BE CONTRACTED UNDER A SEPARATE CONTRACT PER COA WORK ORDER.
- 4,000 PSI AIR-ENTRAINED CONCRETE ISLAND WITH 3/4" AGGREGATE AND 6X6 10/10 WWM
- NEW CONCRETE CURB CUT / ENTRANCE DRIVE, PER CITY OF ALBUQUERQUE STANDARD SPECIFICATIONS, REFER TO STANDARD DETAIL DWG 2426. INSTALL TRUNCATED DOMES AT SIDEWALK CROSSING. THIS WORK TO BE CONTRACTED UNDER A SEPARATE CONTRACT PER
- COA WORK ORDER. NEW CONCRETE CURB AND GUTTER PER CITY OF ALBUQUERQUE SPECIFICATIONS. REFER TO CITY STANDARD DETAIL DWG 2415. THIS
- WORK TO BE CONTRACTED UNDER A SEPARATE CONTRACT PER COA WORK ORDER. NEW MOUNTABLE CURB WHEELCHAIR RAMP AT NEW SIDEWALK PER CITY OF ALBUQUERQUE STANDARD SPECIFICATIONS. REFER TO
- CITY STANDARD DETAIL DWG 2418. INSTALL TRUNCATED DOMES ON RAMP. THIS WORK TO BE CONTRACTED UNDER A SEPARATE CONTRACT PER COA WORK ORDER.
- ACCESSIBLE SIDEWALK RAMP WITH TRUNCATED DOMES. THIS WORK TO BE CONTRACTED UNDER A SEPARATE CONTRACT PER COA WORK ORDER.
- 03200.30 CONCRETE CUT OFF WALL. SEE GRADING AND DRAINAGE PLAN.
- 03200.31 6" WIDE CONCRETE HEADER CURB, TYPICAL. SEE DETAIL A4/AS-101.1 03200.34 NEW CONCRETE VALLEY GUTTER - SEE GRADING AND DRAINAGE PLAN. REFER TO CITY STANDARD DETAIL DWG 2420. THIS WORK TO BE
- CONTRACTED UNDER A SEPARATE CONTRACT PER COA WORK ORDER.
- 6" THICK 4,000 PSI AIR-ENTRAINED CONCRETE SLAB WITH #4 REBAR EACH WAY AT 16" O.C., CENTERED IN SLAB. 03200.44 8" THICK 4,000 PSI AIR-ENTRAINED CONCRETE SLAB WITH #4 REBAR EACH WAY AT 12" O.C., CENTERED IN SLAB.
 - CROSSHATCH INDICATES NEW CONCRETE CURB AND GUTTER, NEW SIDEWALK, NEW DRIVEWAY.
- 03200.46 EXTEND SIDEWALK TO EXISTING STREET SIDEWALK. 03400.02 6'-0" LONG PRE-CAST CONCRETE WHEEL STOP, TYPICAL
 - NEW 6' HIGH CMU WALL. 8"X8"X16" CMU BLOCK WITH 4" X 8" X 16" CAP BLOCK. DARK GRAY COLOR (PETRO BLACK BY CREGO). GROUT ALL
 - CMU REFUSE ENCLOSURE, 8" X 8" X 16" CMU BLOCK WITH 4" X 8" X 16" CAP BLOCK. DARK GRAY COLOR (PETRO BLACK BY CREGO).
- 04800.08 EXISTING 4'-8" HIGH CMU WALL. RAISE TO 6'-0" HIGH. MATCH STYLE AND COLOR OF EXISTING CMU.
 - MECHANICAL EQUIPMENT SCREEN. 8"X8"X16" CMU, DARK GRAY COLOR (PETRO BLACK BY CREGO), 6'-0" HIGH ABOVE FINISH GRADE. SEE FOUNDATION PLAN ON SHEET S-101 AND DETAIL A4/S-131.
 - 3"X4" X 26 GA. GALVANIZED METAL DOWNSPOUT. SECURE TO WALL / COLUMN WITH GALVANIZED METAL STRAPS AT 6'-0" O.C. MAX.
 - SIGNAGE: BUILDING ADDRESS NUMBER. CAST CONCRETE PANEL WITH RECESSED NUMBERS. INSTALL WITH OUTSIDE FACE OF CONCRETE FLUSH WITH CMU WALL.
- VAN ACCESSIBLE DISABLED PARKING SIGN. SEE DETAIL C4 / AS-101. MOTORCYCLE PARKING SIGN. 10100.06
- 10100.10
 - SIGNAGE: BUSINESS SIGN, CAST CONCRETE PANEL WITH RECESSED LETTERS, INSTALL WITH OUTSIDE FACE OF CONCRETE FLUSH WITH CMU WALL.
- 10100.11 RELOCATE EXISTING SIGN "ROAD NARROWS" TO THIS LOCATION.
- 10100.12 SIGNAGE: "PRIVATE ENTRANCE ONLY".
- 10850.02 PROVIDE AND INSTALL RECESSED KNOX BOX. INSTALL 4' TO 6' ABOVE GRADE.
- BIKE RACK. SEE DETAILS ON SHEET AS-101. BASIS OF DESIGN IS SITESCAPES ECHO BIKE RACK "EC2-05-SM" SURFACE MOUNTED (5) BIKE TUBE RACK, OR EQUAL.
- BENCH 21100.01 NEW FIRE HYDRANT AS PART OF THIS PROJECT
- 22100.01 GAS METER.
- 23400.02 HVAC CONDENSING UNIT. SEE MECHANICAL.
- 26200.03 EXISTING POWER POLE TO REMAIN.
- 26200.06 EXISTING POWER POLE GUY WIRE TO REMAIN.
- 26800.03 POLE MOUNTED LIGHT FIXTURE. SEE ELECTRICAL.
- 26800.07 CONCRETE LIGHT BOLLARD, LIGHTS ON TWO SIDES. SEE DETAILS ON SHEET AS-101.1. SEE ELECTRICAL.
- 8" THICK AGGREGATE BASE COURSE (ABC) COMPACTED TO 95% MIN. DENSITY PER ASTM D-1557 OVER EXISTING GRADE COMPACTED TO 95% MIN. IN LIEU OF ABC, CRUSHED RECYCLED CONCRETE MAY BE USED.
- 32100.04 MOTORCYCLE PARKING SPACE, 4'-0" WIDE X 8'-0" LONG, MINIMUM.
- 32100.05 NEW ASPHALT PAVING PER COA STANDARD SPECIFICATIONS. WORK WITHIN THE CITY RIGHT-OF-WAY TO BE CONSTRUCTED UNDER A SEPARATE CONTRACT, PER COA WORK ORDER.
- 32100.10 EXISTING ASPHALT CURB
- 32100.11 4' WIDE ADA PATHWAY ACROSS DRIVE.
- 32300.06 6' HIGH BLACK WROUGHT IRON METAL FENCE.
 - 6'-0" HIGH SLIDING GATE WITH 30'-0" CLEAR OPENING. BASIS FOR DESIGN: HEAVY DUTY CANTILEVER SLIDE GATE WITH TYM-2000 OPERATOR BY TYMETAL CORP. 800.328.4283. GATE WILL OPEN TO THE RIGHT. SUBMIT SHOP DRAWINGS.
- (2) 3'-0" WIDE SWING GATES IN WROUGHT IRON FENCE WITH DROP BOLTS, HEAVY DUTY SELF-SEALED BALL HINGES, SLIDE BOLT LOCK, PADLOCK HASP AND HARDENED STEEL PADLOCK GUARD.
- 32300.09 WROUGHT IRON FENCE EXTENSION FROM NEW WROUGHT IRON FENCE TO EXISTING REFUSE ENCLOSURE.
- 32300.10 NEW 4'-0" HIGH STEEL T-POST FENCE WITH 14 GA. WIRE STRANDS AT 1'-0" O.C.. INSTALL T-POSTS AT 8'-0" O.C. INSTALL FENCE FROM NEW WROUGHT IRON FENCE, ALONG SOUTH PROPERTY LINE, EXTENDING TO EXISTING CMU WALL AT EAST PROPERTY LINE.
 - (2) 15'-0" WIDE X 6'-0" HIGH SWING GATES (MATCH WROUGHT IRON FENCE) WITH DROP BOLTS. HEAVY DUTY HINGES. SLIDE BOLT LOCK. PADLOCK HASP AND HARDENED STEEL PADLOCK GUARD. WELD HINGES TO 4X4X1/4 TUBE STEEL POST SET IN CONCRETE FOOTING.
- 32900.01 4" HIGH METAL EDGING, CONTINUOUS. TOP OF EDGING FLUSH WITH TOP OF ABC.
- 33100.14 NEW WATER METER VALVE BOX.



L&C TRANSPORT OFFICE AND SHOP

112 94th Street NW, Albuquerque, New Mexico 87121 PROJECT ARCHITECT:

LEE GAMELSKY, AIA 22 APRIL 2021 MINOR AMENDMENT TO SITE PLAN / ADMINISTRATIVE AMENDMENT SITE DEVELOPMENT PLAN FOR BUILDING PERMIT

Project #:

DRB PROJECT NO.: 1011638 SITE PLAN

WTB AS-100.1