



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	K09E044	Project Name:	Maverik - 98th and Bluewater		
NPDES Id. No.	NMR1002R2	Location:	9701 Bluewater Rd. NW		
4/26/2021	Owner	Contractor			
Operator	Maverik				
Contact name & title	Kelly Irons				
e-mail	Kelly.Irons@maverik.com				
Contact Phone #	801-335-3815				
COA Inspector	Thomas Evans	Start/End Time:	1:25 PM/1:50 PM		
Construction Phase:	Stabilization				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint Follow Up	
Weather at time of inspection?	clear	Temperature:	~	70	
Estimated date of last storm 0.25" or greater	2/22/2021				
Item Number	Deficiency/ Corrective Action				
1	Areas along West and South frontages are not stabilized. Implement final stabilization controls.				
2					
3					
4					
5					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	8/3/2020	

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 04/30/2021