

CITY OF ALBUQUERQUE



October 21, 2013

Jeffrey Wooten, P.E.
Tierra West, LLC
5571 Midway Park Pl NE
Albuquerque, NM 87109

**Re: Old Dominion Freight Line,
330 Airport Rd NW
Request for 30-day Temporary C.O. –Accepted
Engineer's Stamp dated: 3-27-13, (K10D008A)
Certification dated: 10-16-13**

Dear Mr. Wooten,

Based upon the information in your submittal received 10-16-13, the above reference plan is approved for a release of a 30-day Temporary Certificate of Occupancy by Hydrology.

PO Box 1293

When submitting for Permanent Certificate of Occupancy provide calculations that show the swale along the eastern property line has capacity since flows were diverted to this swale.

Albuquerque

If you have any questions, you can contact me at 924-3986.

New Mexico 87103

Sincerely,

Curtis A. Cherne, P.E.
Principal Engineer—Hydrology Section
Development and Building Services

www.cabq.gov

C: CO Clerk—Katrina Sigala
File
e-mail