

AA

**CITY OF ALBUQUERQUE
ADMINISTRATIVE APPROVAL (AA)- SITE DEV PLAN AMENDMENT
ROUTING & REVIEW SHEET**

APPLICATION #: 13AA-10291	PROJECT #: 1000418
PROJECT NAME: Legacy Church	
APPLICANT or AGENT: Lorenz Design & Consulting	
PHONE # and E-MAIL: 888-6088	
ZONE ATLAS PAGE: K-10	
ADMINISTRATIVE APPROVAL (AA) for:	☒ EPC CASE ☐ DRB CASE

CURRENT PLANNING	DATE RECEIVED: 12-4-13
APPLICATION COMPLETE:	DATE: 12-5-13
APPLICATION INCOMPLETE:	DATE:
ROUTING NEEDED:	☒ YES ☐ NO
COMMENTS: West Rt 66 Sdp applies	
① TIS included	
② 2 copies of proposed site plan and TIS submitted	

TRANSPORTATION (505) 924-3630	DATE RECEIVED:
PLANS DISAPPROVED: NSF	DATE: 12/6/13
PLANS APPROVED:	DATE:
COMMENTS: • SEE SNTS AA-1 & AA-2	
• WAS TRAFFIC IMPACT ASSESSMENT IN RE SARRACINO REVIEWED & APPROVED BY T&E DEPT? VERIFY PRIOR TO APPROVAL	

UTILITIES (505) 924-3989	DATE RECEIVED:
PLANS DISAPPROVED: AP	DATE: 12/11/13
PLANS APPROVED:	DATE:
COMMENTS: - Water line in Sarracino needs to be extended into cul-de-sac. Water line extension should continue into North South access road. The new public water line easement should be established in the east west access road.	

HYDROLOGY (505) 924-3986	DATE RECEIVED:
PLANS DISAPPROVED: GRO	DATE: 2-7-14
PLANS APPROVED:	DATE:
COMMENTS: ① Remove roadway from Public Drainage Easement (or Replat to CHANGE Drainage Easement away from Access Road. ② W.O. for Sarracino Cul-de-Sac must address Drainage ③ Comments on Hydrology Letter to Lorenz Design 2/7/14. Verify Pond sizes	

PLANNING DIRECTOR (505) 924-3860	DATE RECEIVED:
PLANS DISAPPROVED:	DATE:
PLANS APPROVED:	DATE:
COMMENTS:	