

CITY OF ALBUQUERQUE



Call Notes:

1. Any option to move it south of the fence to an easement in the Private Lots? This would avoid complications with the public pond and Drainage Easement. Increased runoff from paving could even be captured in a roadside swale/ponds to keep flows in the easement
2. Issues in the ponds include:
 - a. REPLAT to reduce the Public Drainage Easement size, so that the Roadway is outside the Public Drainage Easement.
 - b. Recalculate the required and available Public pond volume. Tierra Bayita and Unser Storm Drain did not recalculate the required pond volume when flows were diverted south in Unser.
 - c. Provide vehicle barrier or recoverable slope on the fill adjacent to road.
 - d. Revegetation of pond slopes.
 - e.

Called
Dennis Lorenzo
4/7/14

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov