



# **City of Albuquerque**

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

February 2, 1996

J. Bordenave  
Bordenave Designs  
P.O. Box 91194  
Albuquerque, NM 87199

**RE: ZANIOS FOODS (K10-D21A) GRADING PLAN FOR BUILDING PERMIT  
APPROVAL. ENGINEER'S STAMP DATED 1-22-96.**


Dear Mr. Bordenave:

Based on the information provided on your January 23, 1996  
submittal, City Hydrology has the following comments:

1. What is being built? I assume it is the structure  
titled "New Building." A short narrative, explaining  
the intent of the plan would be very helpful.
2. What effect does the building(s) have on the amount of  
runoff generated?
3. Please provide drainage calculations.
4. Show, on the plan sheet, an on-site, temporary bench  
mark

If I can be of further assistance, please feel free to contact me  
at 768-3622.

Sincerely,

  
Lisa Ann Manwill  
Engineering Assoc./Hyd.

c: Andrew Garcia  
File