



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

November 30, 2000

John Arthur Blessen, PE
Claudio Vigil Architects
1305 Tijeras NW
Albuquerque, NM 87102

**Re: Zanios Food Warehouse Addition Phase III Grading & Drainage Plan
Engineer's Stamp dated 9-25-00, (K10/D21A)**

Dear Mr. Blessen,

Based upon the information provided in your submittal dated 9-26-00, the above referenced plan cannot be approved for Site Plan for Building Permit or Building Permit until the following comments are addressed.

- Please provide calculations for the modification of the standpipe in the existing pond. What elevation are the holes you plan to enlarge?
- Why are the rundowns 17 feet wide?
- What is the proposed treatment around new swale? Asphalt is called out but the detail shows dirt.
- The slab on the south appears to need a retaining wall.

If you have any questions, you can contact me at 924-3986.

Sincerely,

Bradley L. Bingham, PE
Sr. Engineer, Hydrology

C: file