




Bordenave Designs



May 5, 1992

City of Albuquerque
Public Works Department
P.O. Box 1293
Albuquerque, NM 87102

Mr. Gilbert Aldaz
Re: Zanos Foods, K10/D21A

Dear Sir:

The subject project was approved for building permit by you on November 26, 1991. Since that time the Owner has found it in his best interest to reorient some of the construction features. The attached plans show the results of that reconfiguration.

The result of the reconfiguration is positive from a drainage point of view in that the ponds are combined making operation and maintenance of the system much more simple. The drainage entrance to the pond is a better configuration and the resulting pond has more capacity. The original Phase I pond had a volume of 115200 cf and the revised pond has a volume of 125800 cf. The original Phase II ponds had a volume of 49010 cf and the revised pond has a volume of 50600 cf.

The drainage patterns and basins remain as they were in the original plan.

Sincerely,

Jean J. (Jake) Bordenave

P.O. Box 91194
Albuquerque, NM 87199-1194
(505) 823-1344