

J Arthur Blessen

Architect / Engineer
Claudio Vigil Architects
1305 Tijeras NW
Albuquerque, New Mexico 87102
(505) 842-1113



December 5, 2000

Bradley Bingham, PE
City of Albuquerque
PO Box 1293
Albuquerque, New Mexico 87103

RE: Zanios Food Warehouse Addition Phase III Grading & Drainage Plan (K10/D21A)

Dear Mr Bingham,

Attached is the revised Grading & Drainage Plan for the Zanios Addition. The orifice modification calculations have been added to the plan.

Per our discussion pipe bollards have been added at the concrete rundown. The bollards will be set 10 feet apart to allow for maintenance

The proposed surface for the new fire lane is gravel and has been noted on the plan.

The retaining wall for the slab at the southeast corner is part of the building foundation as is the retaining wall for the loading docks.

Should you have any questions or require additional information please call.

Sincerely,

J Arthur Blessen, PE

*Rec'd
12/7/00*