

Biazar, Shahab

From: Biazar, Shahab
Sent: Monday, June 03, 2013 2:38 PM
To: 'Martin Sanchez'
Subject: RE: Pre Design Meeting - Labatt Food Service

Hi,

There is an existing drainage file (K10/D21A) for this site. The allowable discharge is 0.1 cfs/ac. Please review City of Albuquerque Drainage file # K10/D21A and let me know if you like to meet.

Thanks and have a nice day.

Shahab Biazar, P.E.

Senior Engineer
Planning Department
Development & Building Services Division
600 2nd St. NW, Suite 201
Albuquerque, NM 87102
t 505-924-3695
f 505-924-3864

From: Martin Sanchez [mailto:Martin@goodwinengineers.com]
Sent: Monday, June 03, 2013 10:22 AM
To: Biazar, Shahab
Subject: Pre Design Meeting - Labatt Food Service

Good morning Mr. Biazar,

I would like to schedule a pre design meeting with you for Labatt Food Service located at 221 Airport Drive N.W. 87121. Please let me know a time that is best for you.

Thank you,

Martin Sanchez, EIT
MARK GOODWIN & ASSOCIATES, PA
(505) 828-2200
(505) 797-9539 fax
martin@goodwinengineers.com