

Bordenave Designs

February 12, 1996

City of Albuquerque
PWD/Hydrology
P.O. Box 1293
Albuquerque, NM 87103

Attn: Lisa Manwill
Re: K10-D21A

Dear Ms. Manwill

The following letter is written in response to your comments dated 02/02/96. The responses are written in the same order as the comments.

1. The proposed construction is labeled "new building" and "new paving" as well as the alteration of the existing concrete rundown.
2. The building increases the amount of runoff generated.
3. The drainage calculations are in the file K10-D21.
4. The existing finish floor has been designated as the TBM since it is this item that must match. The designation has been added to the plan.

The site was designed for the ultimate condition and the future construction was shown on the original submittal. This was done to facilitate future reviews and to assure those in the approval process that the facilities were adequate. The detention pond and controlled outlet was constructed in Phase I of the construction.

Thank you for your review.

Sincerely,


Jean J. (Jake) Bordenave

RECEIVED
FEB 15 1996

P.O. Box 91194
Albuquerque, NM 87199-1194
(505) 823-1344

per what
where?
I see calculations for the SD in Airport.
Nothing for this SD
Yes, but it appears that developed calculations were not considered