



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	K10E023J	Project Name:	WAQ1		
NPDES Id. No.	NMR1003DQ	Location:	7300 Meridian Pl. NW		
4/30/2021	Owner	Contractor			
Operator	Brunacini Development Ltd.				
Contact name & title	Angelo Brunacini				
e-mail	abrunacini@brunacini.com				
Contact Phone #	505-833-2928				
COA Inspector	Thomas Evans		Start/End Time:	11:25 AM/11:40 AM	
Construction Phase:	Earthwork				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint Follow Up	
Weather at time of inspection?	clear		Temperature: ~	67	
Estimated date of last storm 0.25" or greater	4/28/2021				
Item Number	Deficiency/ Corrective Action				
1	Trackout at the East entrance. Sweep trackout by the end of each business day.				
2	Sediment in streets and on sidewalks. Remove sediment by the end of each business day.				
3	Add NPDES Permit number to SWPPP posting				
4					
5					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:		

Notes:	SWPPP posting is up but does not have the Permit ID. Machinery and water truck moving on site.

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 05/03/2021