

CITY OF ALBUQUERQUE

Planning Department
Brennon Williams, Director



Mayor Timothy M. Keller

January 13, 2021
Matt Eblen
McCLURE
1700 Swift St (Suite 100)
North Kansas City, MO, 64116

**Re: WAQ1 Brunacini at 7200 Meridian Pl NW
Erosion and Sediment Control Plan
Engineer's Stamp Date 1/13/2021 (K10E023J)**

Dear Mr. Eblen,

Based upon the information provided in your submittal received 1/13/2021, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit/eNOI for Grading, WO and Building Permit.

The EPA Notice of Intent (NOI) documentation has been reviewed and signed by the City and is attached, so this project is approved for Grading and Building Permit.

Please include a copy of the approved plan along with a signed copy of the signed NOI in the Building Permit application.

If you have any questions, you can contact me at 924-3420 or jhughes@cabq.gov.

Sincerely,

James D. Hughes

James D. Hughes, P.E.
Principal Engineer, Planning Dept.
Development and Review Services