

CITY OF ALBUQUERQUE



July 16, 2008

David B. Thompson, P.E.
Thompson Engineering Consultants, Inc.
P.O. Box 65760
Albuquerque, NM 87193

Re: Duke City Fueling Grading and Drainage Plan
Engineer's Stamp dated 6-24-08 (K10/D028)

Dear Mr. Thompson,

Based upon the information provided in your submittal received 6-27-08, the above referenced plan is approved for Building Permit. Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology.

Per our discussion 7-16-08, rip-rap will be added at the outlet of the existing 8-inch storm drain from the adjacent site. Show this addition on the as-built plan.

Prior to Certificate of Occupancy release, Engineer Certification per the DPM checklist will be required.

If you have any questions, you can contact me at 924-3695.

Sincerely,

Curtis A. Cherne, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: file