

CITY OF ALBUQUERQUE



October 18, 2018

Mark Goodwin, P.E.
Mark Goodwin and Associates
P.O. Box 90606
Albuquerque, NM 87199

**Re: Defined Fitness, Unser Crossing
Erosion and Sediment Control Plan
Engineer's Stamp Date 10-11-18 (K10E045B)**

Dear Mr. Goodwin,

Based upon the information provided in your submittal received 10-11-18, the above referenced plan is not approved to be included in the SWPPP or to apply for an ESC permit/eNOI for grading and Building Permit until the following comments are addressed:

1. Provide existing and proposed grades. The simplest way may be to superimpose BMPs on the grading and drainage plan.
2. Please change "Filler Fabric" to "Filter Fabric" in the Stabilized Construction Entrance detail.

PO Box 1293

Albuquerque

If you have any questions, you can contact me at 924-3420.

NM 87103

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

www.cabq.gov