

# CITY OF ALBUQUERQUE



June 12, 2019

Paul Blanchard, Blanchard Properties, LLC, [rjones@rjonescpa.com](mailto:rjones@rjonescpa.com)  
Cary Bush, Blanchard Construction, [carybush@msn.com](mailto:carybush@msn.com)

Site: Defined Fitness at Unser Crossings

**Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control**

Dear Mr. Blanchard,

1. Self-inspection reports have not been submitted.

Self-inspections and accompanying reports are required once every 14 days and within 24 hours after a precipitation event of 0.25 inch or greater.

**Required mitigation:**

1. Perform self-inspections and document conditions on an inspection report(s) and provide the report(s) to the City.

Self-inspection reports can be hand-delivered, e-mailed or kept on-site. If kept on-site, the location is to be communicated to the City and the location must be accessible to the City during regular work hours.

If the violation is not mitigated within 7 days, the property owner is subject to a fine of \$500/day per the City's Drainage Ordinance.

If you have any questions, you can contact me at 924-3420, [ccherne@cabq.gov](mailto:ccherne@cabq.gov).

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

PO Box 1293

Albuquerque

NM 87103

[www.cabq.gov](http://www.cabq.gov)