

# CITY OF ALBUQUERQUE

August 20, 2015

Philip W. Clark, PE  
Clark Consulting Engineers  
19 Ryan Rd  
Edgewood, NM 87015



**Re: Tam Le Salon  
130 Coors Blvd NW  
Grading and Drainage  
Engineers Stamp Date 8/10/2015 (K10D047)**

Dear Mr. Clark,

Based upon the information provided in your submittal received 8/11/2015, the above referenced Grading and Drainage Plan cannot be approved for Grading Permit or Building Permit until the following comments are addressed.

- Provide roof flows.
- Provide flow calculations for the concrete drainage rundown.
- Verify if the system in the sidewalk is a sidewalk culvert or pvc? Provide calculations for either one.
- An access agreement must be provided from the owners to the south.


PO Box 1293

If you have any questions, you can contact me at 924-3999 or Rudy Rael at 924-3977.

Albuquerque

Sincerely,

New Mexico 87103

  
Shahab Biazar, P.E.  
City Engineer, Albuquerque  
Planning Department

[www.cabq.gov](http://www.cabq.gov)

C: RR/SB  
email