



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	K10E060	Project Name:	7200 Bluewater		
NPDES Id. No.	NMR1003UT	Location:	7200 Bluewater		
2/28/2022	Owner	Contractor			
Operator	M & B Investments Ltd. Co.	GA Brunacini Construction			
Contact name & title	Angelo Brunacini	Angelo Brunacini			
e-mail	abrunacini@brunacini.com	abrunacini@brunacini.com			
Contact Phone #	505-833-2928	505-833-2928			
COA Inspector	Doug Hughes	Start/End Time:	3pm		
Construction Phase:	Earthwork				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Past Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up
Weather at time of inspection?		clear		Temperature: ~	60
Estimated date of last storm 0.25" or greater		1/1/2022			
Item Number	Deficiency/ Corrective Action				
1	Permit coverage was not properly posted, dsign was laying on the ground but still ledgible.				
2	Minor washout next to the container needs disposed in the waste container.				
3					
4					
5					
2.1	Discharge off site? (Y/N)	yes			
4	Self Inspection Reports	Requested	Latest report Date:		

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Doug Hughes (505-803-6155)
jhughes@cabq.gov