City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	K10E061	Project Name:	Murphy Express
NPDES Id. No.	NMR1002W2	Location:	221 Unser Blvd.

7/1/2021	Owner	Contractor	
Operator	Armstrong Central Unser Blvd	Murphy USA	
Contact name & title	Kevin Parker	Gaven Ballinger/Terry Rigdon	
e-mail	kparker@agoc.com	gaven.ballinger@murphyusa.com	
Contact Phone #	602-385-4100	terryrigdon@murphyusa.com	
COA Inspector	**Thomas Evans**	Start/End Time:	10:30 AM/10:35 AM
Construction Phase:	Stabilization		

Type of Inspection:		Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up

Weather at time of inspection?	clear	Temperature: ~	78
Estimated date of last storm 0.25" or greater		6/28/2021	

Item Number	Deficiency/ Corrective Action			
1	Install BMP's until the disturbed area on the North side is fully stabilized.			
2	No posting of NOI permit coverage. Post signage of NOI permit coverage in a location clearly visible to the public.			
3	Self-inspection report not provided upon last request.			
2.1	Discharge off site? (Y/N)	no		
4	Self Inspection Reports	Requested	Latest report Date:	None on file

Notes:	Mulch is still visible, but no growth.

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Thomas Evans (505-803-6215)

tevans@cabq.gov

Thomas Evans 07/06/2021