

City of Albuquerque Stormwater Construction Site Inspection Report

General Information							
ESC File No.	K10E0				D&B U Sell It		
NPDES Id. No. NMR1006GO & 69D Location: 401 Unser Blvd. and 8530 Bluewater Rd. NW							ld. NW
	3/2025	Owner			Contractor		
Operator		D&B Limited Trust, LLC			Alliance Paving Company		
Contact name & title		Miriam Ruiz			Jose L. Flores & Joseph Cruz		
e-mail		miriamruiz@yahoo.com dblimitedtrust					
Contact Phone #		505-884-3578			505-991-2467		
COA Inspector		Chancellor English			Start/End Time: 11am		
Construction Phase:					g, utilities		
	spection:	Regular	Storm Event		Event >0.25"	311/Complaint	Follow Up
Weather at time of i		nspection? clear			Temperature: ~ 75		
Estimated	date of last s	torm 0.25" or greater			6/2/2025		
Item							
Number	Deficiency/ Corrective Action						
1	SWPPP - The SWPPP and self-inspection reports were missing from the bucket on the back of the						
	posting sign in violation of CGP Parts 4.7.3 and 7.3. Required mitigation: You must keep a current						
	copy of your SWPPP and all self-inspection reports at the site or at an easily accessible location, so that						
	it can be made immediately available at the time of an on-site inspection per CGP Parts 4.7.3 and 7.3.						
	in can be made ininiediately available at the time of all off-site hispection per CGP Parts 4.7.3 and 7.3.						
2	Cadinaant baal				on Dividional Di	lucario de la decada	fail f
2	Sediment has been discharged into the intersection of Unser Blvd and Bluewater Rd due to a failure of						
	the silt fence in violation of CGP Part 2.1.4. Required mitigation: Ensure all stormwater controls are						
	maintained and remain in effective operating condition during permit coverage per CGP Part 2.1.4.						
	Remove the deposited sediment by sweeping, shoveling, or vacuuming. You are prohibited from						
	hosing or sweeping the material into any constructed or natural drainage feature.						
2.1	Discharge off site?	(Y/N)	no				
4	Self Inspect	ion Reports	No	Latest re	port Date:	N/A	
Notes:							
<u> </u>							
The SWPPP bucket has no lid and has water in it.							

City of Albuquerque Stormwater Inspector Signature and date: 6/6/2025

Contact information: Chancellor English 505-924-3325

cenglish@cabq.gov

Chancellor English