

CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Director



Mayor Timothy M. Keller

May 12, 2025

David Soule, P.E.
Rio Grande Engineering
P.O. Box 93924
Albuquerque, NM 87199

**RE: 6601 Delia Road SW
Grading and Drainage Plan
Engineer's Stamp Date: 4/30/25
Hydrology File: K10D073
Case # HYDR-2025-00155**

Dear Mr. Soule:

Based upon the information provided in your submittal received 04/30/2025, the Grading & Drainage Plan is not approved for Building Permit and Grading Permit. The following comments need to be addressed for the approval of the above referenced project.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

1. An SO-19 Permit will be required and should be included on the request. Please include the [standard SO-19](#) notes on the grading plan.
2. Stormwater discharges across the sidewalk are not allowed on collector roads and above; provide sidewalk culverts or drain lines through the curb.

As a reminder, if the project total area of disturbance (including the staging area and any work within the adjacent Right-of-Way) is 1 acre or more, then an Erosion and Sediment Control (ESC) Plan and Owner's certified Notice of Intent (NOI) is required to be submitted to the Stormwater Quality Engineer (Doug Hughes, PE, jhughes@cabq.gov, 505-924-3420) 14 days prior to any earth disturbance.

If you have any questions, please contact me at 505-924-3314 or amontoya@cabq.gov.

Sincerely,

Anthony Montoya, Jr., P.E., CFM
Senior Engineer, Hydrology
Planning Department, Development Review Services