



City of Albuquerque
Stormwater Construction Site
Inspection Report

General Information

Project Name and Location	Turn 2 over to DMD March 18		
Site Contact Name & Agency		ESC File No.	K115001
Date of Inspection		Start/End Time	
Inspector Name, COA Dept.	Curtis Cherne, Stormwater Quality		
Describe Present Phase of Construction			

Type of Inspection:

- Regular • During storm event • Post-storm event (> 0.5 inch) • 311 / Complaint Response • Follow-Up

Weather Information

Weather at time of this inspection?	Temperature: ~ _____ F°
• Clear • Cloudy • Rain • Sleet • Fog • Snowing • Windy	

Has there been a storm event since the site was Permitted? • Yes • No
Amount: • < 1/4" • 1/4" to 3/4" • > 3/4" • Snow _____"

Erosion & Sediment Control Inspection

Entrance / Track-Out
Sediment Controls / Silt Fence, Inlet Protection, Wattles, etc.
Inspection Reports
Erosion Controls
Housekeeping/Pollutant Controls
Debris/Pollutants/Sediment in MS4
Notes

Is site being maintained in compliance with the Drainage Ordinance ? • Yes • No

Signature

Date



City of Albuquerque
Stormwater Construction Site
Inspection Report

General Information

Project Name and Location	WESTSIDE INTERCEPTOR @ YUCCA CENTRAL & 59 TH		
Site Contact Name & Agency	JOSE PINON AUI INC.	ESC File No.	K11E001
Date of Inspection	11-8-17	Start/End Time	9:00 / 9:30
Inspector Name, COA Dept.	Stanice "Totten" Elliot, Stormwater Quality		
Describe Present Phase of Construction	INSTALLING UTILITIES ON 59 TH		

Type of Inspection:

☒ Regular ☐ During storm event ☐ Post-storm event (> 0.5 inch) ☐ 311 / Complaint Response ☐ Follow-Up

Weather Information

Weather at time of this inspection?

Temperature: ~43 F°

☒ Clear ☐ Cloudy ☐ Rain ☐ Sleet ☐ Fog ☐ Snowing ☐ Windy

Has there been a storm event since the site was Permitted? ☐ Yes ☐ No

Amount: ☒ < 1/4" ☐ 1/4" to 3/4" ☐ > 3/4" ☐ Snow _____"

Erosion & Sediment Control Inspection

Entrance / Track-Out TRACK OUT ON YUCCA AND PALM

Sediment Controls / Silt Fence, Inlet Protection, Wattles, etc.

ONE WADDLE ON CHURCHILL NEEDS REPLACING

Erosion Controls NO

Housekeeping/Pollutant Controls OK

Debris/Pollutants/Sediment in MS4 NO

Notes JUSTIN M. FROM DMD HAD BEEN YESTERDAY. THEY HAD ALREADY BEEN TOLD TO REMOVE DIRT FROM YUCCA AND PALM. THEY WILL START REMOVING DIRT 3 DAY A WEEK INSTEAD OF 1 DAY A WEEK

Is site being maintained in compliance with the Drainage Ordinance? ☒ Yes ☐ No

Signature

Date

Cherne, Curtis

From: Dery, Victoria A. <vdery@abcwua.org>
Sent: Tuesday, August 22, 2017 5:51 PM
To: Cherne, Curtis
Cc: Dery A. Victoria; jamesa@auinc.net; MBrown@carollo.com; Koike L. Lorraine; John Malone
Subject: Re: Westside INterceptor Construcion Site Inspection - PASS with comments

Curtis,
Thanks for the recommendations. I'll pass this on to the contractor.
Victoria

Sent from my iPhone

On Aug 22, 2017, at 4:05 PM, Cherne, Curtis <CCherne@cabq.gov> wrote:

Victoria,
Good afternoon.
I went out to the above referenced project today for an inspection.
AUI was sweeping one of the streets while I was there and they appear to be relatively on top of things. Thanks.

A couple items were relayed to AUI:

1. Remove sediment from Central Ave. I mentioned a regular track-out pad, but due to residents having to use the street(s) that is not possible. I mentioned that some gravel they had laying around could be used to help minimize track-out.
2. A couple of inlets required maintenance of the inlet protection (the mat on the grate). I also told the contractor that filter socks would work better than straw wattles on the inlets as they allow water to pass through, whereas straw wattles do not. It may help them keep the site a little less muddy.

Curtis Cherne, PE, QCIS
Principal Engineer
Stormwater Quality
COA
505-924-3420

"Cement (concrete, stucco, mortar...) pollution is preventable.....Let's prevent it. Thank you."

<inlet_protection_maintenance.jpg>

<central_track-out.jpg>

Cherne, Curtis

From: Cherne, Curtis
Sent: Tuesday, August 22, 2017 4:05 PM
To: Dery A. Victoria
Subject: Westside INTERceptor Construcion Site Inspection - PASS with comments
Attachments: inlet_protection_maintenance.jpg; central_track-out.jpg

Victoria,

Good afternoon.

I went out to the above referenced project today for an inspection.

AUI was sweeping one of the streets while I was there and they appear to be relatively on top of things. Thanks.

A couple items were relayed to AUI:

1. Remove sediment from Central Ave. I mentioned a regular track-out pad, but due to residents having to use the street(s) that is not possible. I mentioned that some gravel they had laying around could be used to help minimize track-out.
2. A couple of inlets required maintenance of the inlet protection (the mat on the grate). I also told the contractor that filter socks would work better than straw wattles on the inlets as they allow water to pass through, whereas straw wattles do not. It may help them keep the site a little less muddy.

Curtis Cherne, PE, QCIS

Principal Engineer

Stormwater Quality

COA

505-924-3420

"Cement (concrete, stucco, mortar...) pollution is preventable.....Let's prevent it. Thank you."

Cherne, Curtis

From: Cherne, Curtis
Sent: Friday, December 09, 2016 2:02 PM
To: Dery A. Victoria
Subject: Westside Interceptor SWPPP inspection-PASS

Victoria,

Good afternoon.

I stopped by the Westside Interceptor project yesterday.

The implementation of the sediment BMPs as shown on your plan was good and I did not see any track-out.

At first I was wondering why the cattle-guard inlet did not have protection (Dandy bag), but checked the plan and it was approved without. Must have figured small amounts of drainage would stay in the gutter.

Thank you for your efforts.

Have a good weekend.

Curtis Cherne, PE, QCIS
Stormwater Quality Engineer
COA
505-924-3420

"Cement (concrete, stucco, mortar...) pollution is preventable.....Let's prevent it. Thank you."



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name and Location	Westside Interceptor at Yucca Canyon Churchill and 50th		
Site Contact Name & Agency	Victoria Dery ABCWWA	Contact Phone #/ E-mail	Vdery@ abcwwa.org
Date of Inspection	12-8-16	Start/End Time	3:00 / 3:15
Inspector Name, COA Dept.	Curtis Cherne, Stormwater Quality		
Inspector Phone / E-mail	505-924-3420/ccherne@cabq.gov		
Inspector Qualifications	Qualified Compliance Inspector of Stormwater- Stormwater One		
Describe Present Phase of Construction	Churchill St.		

Type of Inspection:

☒ Regular • During storm event • Post-storm event (> 0.5 inch) • 311 / Complaint Response • Follow-Up

Weather Information

Weather at time of this inspection?

Temperature: ~ 40 F°

☒ Clear • Cloudy • Rain • Sleet • Fog • Snowing • Windy

Has there been a storm event since the site was Permitted? • Yes • ☒ No

Amount: • < 1/4" • 1/4" to 3/4" • > 3/4" • Snow "

Erosion & Sediment Control Inspection

- Entrance / Track-Out no entrance - no track-out
- Sediment Controls / Silt Fence, Check Dams, Waddles, etc. cattle guard inlet - no protection - all other inlet protection look good - ✓ plan
- Erosion Controls / Mulch, Seed, no
- Housekeeping/Pollutant Controls ok
- Debris/Pollutants/Sediment in MS4 no
- Notes _____

Is site being maintained in compliance with the Drainage Ordinance? ☒ Yes • No

Signature

Date



City of Albuquerque
Stormwater Construction Site
Inspection Report

General Information

Project Name and Location	WESTSIDE INTERCEPTOR @ YUCCA CENTRAL CHURCHILL & 50 TH		
Site Contact Name & Agency	VICTORIA DERY ABCWUA DINO	ESC File No.	K11E001
Date of Inspection	8-22-17	Start/End Time	8:55 / 9:38 70°
Inspector Name, COA Dept.	Curtis Cherne, Stormwater Quality		
Describe Present Phase of Construction	INSTALLING UTILITIES ON 59 TH		

Type of Inspection:

- ☒ Regular ☐ During storm event ☐ Post-storm event (> 0.5 inch) ☐ 311 / Complaint Response ☐ Follow-Up

Weather Information

Weather at time of this inspection? Temperature: ~ 70 F°
☒ Clear ☐ Cloudy ☐ Rain ☐ Sleet ☐ Fog ☐ Snowing ☐ Windy

Has there been a storm event since the site was Permitted? ☒ Yes ☐ No

Amount: ☐ < 1/4" ☒ 1/4" to 3/4" ☐ > 3/4" ☐ Snow _____

Erosion & Sediment Control Inspection

Entrance / Track-Out CENTRAL & 59TH MINOR TRACK OUT REMOVE SEDIMENT ON SIDEWALK ON CENTRAL INTERSECTION, REMOVE SEDIMENT ON PALM, REPLACE WAFFLE SW. DOORS CHURCHILL
Sediment Controls / Silt Fence, WAFFLE IN CATCHGUARD, REMOVE SEDIMENT (FILTER SOCK) 59TH & CHURCHILL
Inlet Protection, Wattles, etc. REPLACE WAFFLE SE CORNER 59TH & CHURCHILL

Erosion Controls NO
Housekeeping/Pollutant Controls _____

Debris/Pollutants/Sediment in MS4

Notes SWEEPING WEST OF 59TH ON YUCCA

Is site being maintained in compliance with the Drainage Ordinance? ☒ Yes ☐ No

Signature

Date