

CITY OF ALBUQUERQUE
PLANNING DEPARTMENT
DEVELOPMENT SERVICE / HYDROLOGY SECTION

DATE: 5-18-12 (6-14-12)
CONFERENCE RECAP

ZONE ATLAS PAGE NO: K11/0080

DRAINAGE FILE: NA

ZONING: /

DRB:

SUBJECT: /

STREET ADDRESS (IF KNOWN): 60th st north of central

SUBDIVISION NAME: /

APPROVAL REQUESTED:

ATTENDANCE: John Jacques, ^{Miller} enla-
Curtis Cherne

FINDINGS:

The site can free discharge into 60th st.

A concrete channel should be built along southern property line to divert flows to 60th st thru a sidewalk culvert.

An SO-19 permit will be required for each sidewalk culvert. [(Entrance condition) (once in SW culvert
1.9 cfs/lf (6 cfs ±) need calc)]

A grading and drainage plan is required for SO-19 permit approval

THE UNDERSIGNED AGREES THAT THE ABOVE FINDINGS ARE SUMMARIZED ACCURATELY AND ARE SUBJECT TO CHANGE IF FURTHER INVESTIGATION REVEALS THAT THEY ARE NOT REASONABLE OR THAT THEY ARE BASED ON INACCURATE INFORMATION.

SIGNED: Curtis A. Cherne
NAME (PRINT): Curtis A. Cherne

SIGNED: John Jacques
NAME (PRINT): JOHN JACQUEZ

****NOTE**** PLEASE PROVIDE A COPY OF THIS RECAP WITH YOUR DRAINAGE SUBMITTAL.

Tim. C-18-12

I drew poly

pls enter into

access / Grn book

Center