

CITY OF ALBUQUERQUE

PLANNING DEPARTMENT – Development & Building Services



March 10, 2014

Dennis Lang, P.E.
Adams Engineering
910 South Kimball Avenue
Southlake, Texas 76092

Richard J. Berry, Mayor

RE: **Church's Chicken #695 – 5407 Central Ave. NW**
Request for Permanent Certificate of Occupancy

File **K11-D081**

Temporary C.O. – Accepted = 30-Days
G&D Plan - Engineer's Stamp: 09-19-13
Certification dated: 03-08-2014

Dear Mr. Lang,

Based upon the information provided in your Drainage Certification received 3-10-2014, the above referenced Certification is NOT acceptable for a release of a Permanent Certificate of Occupancy (CO) by Hydrology.

PO Box 1293

Albuquerque

I was able to review the surveyors As-Built Survey notes, and your separate Drainage Certification statement, and am basing this Temporary CO on that information. To obtain a release of the Permanent CO from Hydrology, we request that your certification statement be included on a copy of the Approved Grading and Drainage Plan, with the As-Built Survey information and surveyors certification included.

New Mexico 87103 **The above referenced Certification is acceptable for release of a 30 day Temporary Certificate of Occupancy by Hydrology.**

www.cabq.gov

If you have any questions, please contact me at grolson@cabq.gov or phone 505-924-3994.

Sincerely,

Gregory R. Olson, P.E.
Senior Engineer

Orig: Drainage file K11-D081
c.pdf Addressee via Email: Dennis.Lang@Adams-Engineering.com
ec: Bob Golden, NMGolden@aol.com