

City of Albuquerque Stormwater Construction Site Inspection Report

General Information							
Project Name:		Sunset Villa					
Location:		Sunset Garder	ns and Sunset Rd				
Site Contact Name &		Phil L Sunset Villa		ESC File No.	K12E003		
Agency		phillindborg(@comcast.net	NPDES Id. No.		NMR12AX70	
Inspection	Date:			30/1100hro			
CoA Stormwater Inspector: Timothy E. Sims							
Construction Phase: earthwork							
Type of Inspection:		Regular Storm Event		Post Storm Event >0.25" 311/Complaint x Follow Up			
Weath	er at time of	inspection?	Clou	dy	Tempe	rature: ~ 55*	
Estimated date of last storm 0.25" or greater 11/25/2019							
Item							
Number	Deficiency/ Corrective Action						
1	Garden Way - all remove dirt ramps. Typical SWQ policy is all sediment in street						
	requires immediate mitigation when occupied with home owners.						
2	Tyrack Lane - all dirt ramps require mitigation and cut backs behind curbs.						
3	Please provide latest SWPPP self-inspection reports.						
2.1	Discharge off site?	(Y/N)	No	1			
	_	tion Reports	requested	Latest rep	ort Date:	7/8/2019	
4	Sell ilisped	tion Reports	requested	Latestie	ort Date.	7/8/2019	
Notes:							

 ${\bf City\ of\ Albuquerque\ Stormwater\ Inspector\ Signature\ and\ date:}$

Contact information: Timothy E. Sims - (505) 803-6155

tsims@cabq.gov

03/30/20