



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name and Location	Corner Shell Central & Arroyo		
Site Contact Name & Agency	John Belanich Tecolote Resources	ESC File No.	113501 112 E015C
Date of Inspection	2-7-10	Start/End Time	1:50/1:55
Inspector Name, COA Dept.	Curtis Cherne, Stormwater Quality		
Describe Present Phase of Construction	Stabilized		

Type of Inspection:

☒ Regular • During storm event • Post-storm event (> 0.5 inch) • 311 / Complaint Response • Follow-Up

Weather Information

Weather at time of this inspection?

Temperature: ~ 55 F°

☒ Clear • Cloudy • Rain • Sleet • Fog • Snowing • Windy

Has there been a storm event since the site was Permitted? ☒ Yes • No

Amount: • < 1/4" • 1/4" to 3/4" • > 3/4" • Snow _____

Erosion & Sediment Control Inspection

Entrance / Track-Out	NA
Sediment Controls / Silt Fence, Inlet Protection, Wattles, etc.	Stabilized
Inspection Reports	
Erosion Controls	gravel, ponds
Housekeeping/Pollutant Controls	
Debris/Pollutants/Sediment in MS4	
Notes	

Is site being maintained in compliance with the Drainage Ordinance? ☒ Yes • No

Signature

Date



City of Albuquerque
Stormwater Construction Site
Inspection Report

General Information

Project Name and Location	CORNER SHELL		
Site Contact Name & Agency	ROBERT GARBER RICHARD	ESC File No.	K12E015C
Date of Inspection	11-8-17	Start/End Time	8:40 / 8:50
Inspector Name, COA Dept.	Stanice "Totten" Elliott Stormwater Quality		
Describe Present Phase of Construction	FRAMING & GRADING		
Type of Inspection:	<input checked="" type="checkbox"/> Regular <input type="checkbox"/> During storm event <input type="checkbox"/> Post-storm event (> 0.5 inch) <input type="checkbox"/> 311 / Complaint Response <input type="checkbox"/> Follow-Up		

Weather Information

Weather at time of this inspection?	Temperature: ~ 40 F°
<input checked="" type="checkbox"/> Clear <input type="checkbox"/> Cloudy <input type="checkbox"/> Rain <input type="checkbox"/> Sleet <input type="checkbox"/> Fog <input type="checkbox"/> Snowing <input type="checkbox"/> Windy	
Has there been a storm event since the site was Permitted? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Amount: <input checked="" type="checkbox"/> < 1/4" <input type="checkbox"/> 1/4" to 3/4" <input type="checkbox"/> > 3/4" <input type="checkbox"/> Snow _____	

Erosion & Sediment Control Inspection

Entrance / Track-Out	OK
Sediment Controls / Silt Fence, Inlet Protection, Wattles, etc.	INLET PROTECTION NEEDS REPLACING <i>silt fence</i>
Erosion Controls	OK
Housekeeping/Pollutant Controls	OK
Debris/Pollutants/Sediment in MS4	NO
Notes	TALKED TO ROBERT ON MY WAY OUT. SAID HE TAKE CARE OF INLET PROTECTION RIGHT NOW.

Is site being maintained in compliance with the Drainage Ordinance?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<i>[Signature]</i>	11-8-17
		Signature	Date



City of Albuquerque
Stormwater Construction Site
Inspection Report

General Information

Project Name and Location	CORNER SHELL		
Site Contact Name & Agency	ROBERT GARBER HART	ESC File No.	K12E015C
Date of Inspection	10-17-17	Start/End Time	9:30 / 9:50
Inspector Name, COA Dept.	Stanice "Totten" Elliott, Stormwater Quality		
Describe Present Phase of Construction	INSTALLING UTILITIES		
Type of Inspection:	<input checked="" type="checkbox"/> Regular <input type="checkbox"/> During storm event <input type="checkbox"/> Post-storm event (> 0.5 inch) <input type="checkbox"/> 311 / Complaint Response <input type="checkbox"/> Follow-Up		

Weather Information

Weather at time of this inspection?	Temperature: ~ 54 F°
<input checked="" type="checkbox"/> Clear <input type="checkbox"/> Cloudy <input type="checkbox"/> Rain <input type="checkbox"/> Sleet <input type="checkbox"/> Fog <input type="checkbox"/> Snowing <input type="checkbox"/> Windy	
Has there been a storm event since the site was Permitted? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Amount: <input checked="" type="checkbox"/> < 1/4" <input type="checkbox"/> 1/4" to 3/4" <input type="checkbox"/> > 3/4" <input type="checkbox"/> Snow _____"	

Erosion & Sediment Control Inspection

Entrance / Track-Out	NO TRACK-OUT PAD CONSTRUCTION SITE SURROUNDED BY PAVEMENT, MINOR TRACK-OUT
Sediment Controls / Silt Fence, Inlet Protection, Wattles, etc.	INLET PROTECTION NEEDS MAINTENANCE

Erosion Controls	
Housekeeping/Pollutant Controls	DUMSTER ON SITE

Debris/Pollutants/Sediment in MS4	NO
Notes	WILL GET LABORS OUT TO SWEEP PARKING LOT AND CLEAN INLET PROTECTION

Is site being maintained in compliance with the Drainage Ordinance ? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<i>[Signature]</i>	10-17-17
	Signature	Date