HYDROLOGY K13/D4 3 PLANS

K13/D4

3 PLANS

CITY OF ALBUQUERQUE

ALBUQUERQUE, NEW MEXICO

INTER-OFFICE CORRESPONDENCE

December 10, 1980

REF. NO._____

TO: C. W. Volz, Chief Building Official

FROM: R. S. Heller, City Engineer

SUBJECT: 920 Alcade Place S.W.

The purpose of this letter is to request your assistance in expediting the processing of the plans for a new City owned building at the subject address.

The building is a pre-engineered building with no mechanical or electrical systems and will be used for storage.

I understand the architect, Ken Hovey, will submit for a "foundation only" approval and then for approval of the superstructure.

Your help in this matter will be appreciated.

JAD/RSH/fs

RECEIVED

DEC 15 1980

ALBUQUERQUE
CODE ADMINISTRATION
DIVISION

X SS BASED ON
FURNISHED BY REQUE
LEGAL DESCRIPTION
SET TO ☐ CURB ☐ PROPERTY
IN ACCORDANCE WITH
COMM. ORDINANCE # 210
BY
5 per Mr Davis

SU-2
SU-1
2-79-10-5

12-12-8

DISAPPROVED FOR DRAINAGE
1-6-81
DATE
SIGNATURE
P.E.
TITLE
Formal Drainage Report required. Submit report to the City Engineer's office

CONDITIONALLY
APPROVED FOR DRAINAGE
1-12-81
DATE
SIGNATURE
P.E.
TITLE
ADVISE DRAINAGE INSPECTOR
WHEN GRADING EXECUTED
PENDING AGREEMENT ON
PONDING REQUIREMENTS

DISAPPROVED FOR DRAINAGE
DATE
SIGNATURE
TITLE